

File Original and  
First Copy with the  
STATE ENGINEER,  
SALEM, OREGON

**WATER WELL REPORT**  
STATE OF OREGON

State Well No. 10/3W-19 C(11)  
State Permit No. GP83

RECEIVED  
OCT 14 1958  
SALEM, OREGON

G 1024  
LINN  
4884

**(1) OWNER:**  
Name Wm. Brennan  
Address Rt. 2  
Albany Oregon

**(2) LOCATION OF WELL:**  
County Linn Owner's number, if any—  
1/4 1/4 Section 19 T. 10 S R. 3 W W.M.  
Bearing and distance from section or subdivision corner  
S. 64° 30' W 21.8 ch.

**(3) TYPE OF WORK (check):**  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

**(4) PROPOSED USE (check):**      **(5) TYPE OF WELL:**  
Domestic  Industrial  Municipal  Rotary  Driven   
Irrigation  Test Well  Other  Cable  Jetted   
Dug  Bored

**(6) CASING INSTALLED:**      Threaded  Welded   
10 " Diam. from 0 ft. to 40 ft. Gage Std.  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**      Perforated?  Yes  No  
Type of perforator used Mills  
SIZE of perforations      in. by      in.  
60 perforations from 17 ft. to 39 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**      Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
" Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**  
Static level 18 ft. below land surface Date 7-11  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by:  
[Signed] William C. Brennan Date 7-17, 1958  
(Owner)

**(11) WELL TESTS:**      Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield:      gal./min. with      ft. drawdown after      hrs.  
"      "      "      "      "  
"      "      "      "      "  
Bailer test 60 gal./min. with off bottom ft. drawdown after      hrs.  
Artesian flow      g.p.m. Date \_\_\_\_\_  
Temperature of water      Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**      Diameter of well 10 inches.  
Depth drilled 50 ft. Depth of completed well 50 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
light top soil	0	6
yellow clay	6	27
light river gravel	27	32
fine dark sand	32	39
large rock mixed with blue clay	39	40
blue clay	40	50

Work started 7-9 1958 Completed 7-11 1958

**(13) PUMP:**  
Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Well Driller's Statement:**  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Klaus & Beasley Drilling Co.  
(Person, firm, or corporation) (Type or print)

Address 1515 Walnut Albany

Driller's well number \_\_\_\_\_

[Signed] Ed Beasley  
(Well Driller)

License No. 208 Date 7-11, 1958