

RECEIVED

STATE OF OREGON WATER WELL REPORT MAR 26 1986

(as required by ORS 537.785)

PLEASE TYPE or PRINT IN INK

WATER RESOURCES DEPT

Linn 499

115/2W-8dc

(for official use only)

(1) OWNER:

SALEM, OREGON

Name LOUIE MARTENIC Address Rt. 1 Box 255 m City Albany, Oregon State

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [] Driven [] Domestic [X] Industrial [] Municipal [] Rotary Mud [] Dug [] Irrigation [] Thermal [] Withdrawal [] Reinjection [] Cable [X] Bored [] Other: Piezometric [] Grounding [] Test []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Thermal [] Withdrawal [] Reinjection [] Grounding [] Test []

(5) CASING INSTALLED:

Steel Threaded [X] Plastic Welded []

6 + 1/2 0 90 Diam. from ft. to ft. Gauge 250

LINER INSTALLED:

Steel Threaded [] Plastic Welded []

(6) PERFORATIONS:

Perforated? [] Yes [X] No []

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No []

Manufacturer's Name Type Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom? Air test gal./min. with drill stem at ft. hrs. Bailer test 60 gal./min. with 42 ft. drawdown after 1 hrs. Artesian flow g.p.m. Temperature of water 510 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [] No [X]

Well seal—Material used CEMENT Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 6 10 in. Diameter of well bore below seal 6 10 in. Amount of sealing material 11 sacks [X] pounds [] How was cement grout placed? Method C

Was pump installed? Type HP Depth ft.

Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.

Did any strata contain unusable water? [] Yes [X] No

Type of Water? depth of strata

Method of sealing strata off

Was well gravel packed? [] Yes [X] No Size of gravel: ft.

Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Linn SW 1/4 SE 1/4 of Section 8 Township 11 S Range 2 W WM.

Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

Rt. 1 Box 255 m Albany Oregon

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 14 ft.

Static level 1 ft. below land surface. Date 3/15/86

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 93 ft. Depth of completed well 93 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: BROWN SOIL (0-3), BROWN SOIL & GRAVEL (3-14), BROWN SOIL SAND GRAVEL (14-35), BLUE CLAY & GRAVEL (35-45), BLUE CLAY (45-51), GRAVEL (51-54), BLUE CLAY & GRAVEL (54-83), GRAVEL (83-91), BLUE CLAY (91-93).

Date work started 3/10/86 /completed 3/15/86

Date well drilling machine moved off of well 3/15/86 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date 19

(bonded) Water Well Constructor Certification:

Bond 615 Issued by: (number) (Surety Company Name)

On behalf of RIDGERS WELL DRILLING (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) Pat Ridger (Water Well Constructor)

(Dated) 3/16/86

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690