

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON APR 3 1975

State Well No. 115/2W-9CA

within 30 days from the date of well completion.

(Please type or print)

STATE ENGINEER

State Permit No.

SALEM, OREGON

(1) OWNER:

Name Robert Mercer
Address Rt. 1, Box 285
Albany, Oregon 97321

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []
Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

12" Diam. from 0 ft. to 38 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? [x] Yes [] No. torch
Type of perforator used
Size of perforations 1/8 in. by 10 in.
64 perforations from 20 ft. to 30 ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [x] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 450 gal./min. with 25 ft. drawdown after 2 hrs.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 19 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [x] Yes [] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Linn Driller's well number 18375D
NE 1/4 SW 1/4 Section 8 9 T. 11S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 5 ft.
Static level 5 ft. below land surface. Date 3-31-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 40 ft. Depth of completed well 40 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Contains entries for sandy loam, gravel & sand, and brown sand & small gravel.

Work started 3-29 1975 Completed 3-31 1975
Date well drilling machine moved off of well 3-31 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date 4-2, 1975
Drilling Machine Operator's License No. 594

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric & Pump
Address 626 W. Queen Ave. - Albany, Or. 97321
[Signed] Larry E. Schoen
Contractor's License No. 513 Date 4/2, 1975