

RECEIVED

Original Log Filed : August 17, 1966 was

LINN

5041

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 10/36-23A

State Permit No. G-3635

(1) OWNER:

Name Ernest H. Aermi
Address Route 1 Box 276
Jefferson Oregon

(2) LOCATION OF WELL:

County Linn Driller's well number 32
1/4 Section 23 T. 10S R. 3W W.M.
Bearing and distance from section or subdivision corner
220 feet South - 196 feet West from North East corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

8" Diam. from +10 ft. to 24 ft. Gage .250
Threaded [ ] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No
Type of perforator used Acetylene cutting Torch
Size of perforations 1/2 in. by 10 in.
24 perforations from -13 ft. to 24 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Bentonite
Depth of seal 10 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [ ] Yes [X] No
Was a drive shoe used? [ ] Yes [X] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 11 ft. below land surface Date 8/6/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? owner
Yield: 234 gal./min. with 4 ft. drawdown after 8 hrs.
Bailer test 22 gal./min. with 70 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 8 in
Depth drilled 25 ft. Depth of completed well 25 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include SANDY LOAM (0-8), LARGE + MEDIUM GRAVEL (8-24), MIXED WITH COURSE SAND, VERY HARD RIVER BED (24-25).

Work started 8/6/ 19 66 Completed 8/6/ 19 66
Date well drilling machine moved off of well 8/10/ 19 66

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Frank Wagy - Well Drilling
Address 2435 Pine Lane - Albany Ore
Drilling Machine Operator's License No. 364
[Signed] Frank Wagy
Contractor's License No. 423 Date 8/8/ 19 66