

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
WATER WELL REPORT
STATE OF OREGON
(Please type or print)
STATE ENGINEER
OREGON

Linn
51745
G-4182

State Well No. 10/2w-3 **OR**
State Permit No. _____

(1) OWNER:

Name Mr. Joe Solis
Address P.O. Box #7
Brooks, Ore.

(2) LOCATION OF WELL:

County Linn Driller's well number 213
SW $\frac{1}{4}$ SE $\frac{1}{4}$ Section #3 T. 10S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

PROPOSED USE (check): (5) **TYPE OF WELL:**

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 100 ft. Gage 250
6" Diam. from 90 ft. to 100 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills
Size of perforations _____ in. by _____ in.
(8) 750 perforations from _____ ft. to _____ ft. _____ ft.
(9) 15 perforations from _____ ft. to _____ ft. _____ ft.
perforations from _____ ft. to _____ ft. _____ ft.
perforations from _____ ft. to _____ ft. _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
in. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite puddle clay
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 3/13/67
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Stettler
Yield: 175 gal./min. with 30 ft. drawdown after 1 hrs.
" 250 " 42 " " 1 "
" 325 " 57 " " 1 "
~~Yield~~ 425 ~~gpm.~~ 67 ~~drawdown~~ 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 100 ft. Depth of completed well 100 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0'	2'
Clay (yellow-tan-firm)	2'	12'
Clay-gravel (brown-firm)	12'	22'
Silted gravel	22'	28'
Cement gravel	28'	35'
Silted gravel	35'	40'
Cement gravel	40'	49'
Silted gravel	49'	50'
River gravel-sand (loose)	50'	55'
Cement gravel	55'	80'
Pea gravel-sand with brown clay layers (soft-loose)	80'	90'
Sandy shale-sandstone-sand	90'	95'
clay-gravel (firm)	95'	100'

Installed 10' long 6" liner from at bottom of well to cope with sand layer. Welded on metal ring seal to top of 6" liner.

Work started 3/1/67 19 Completed 3/13/67 19
Date well drilling machine moved off of well 3/13/67 19

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pete Tolmasoff Well Drilling
(Person, firm or corporation) (Type or print)
Address Turner, Ore.

Drilling Machine Operator's License No. 320
[Signed] Pete Tolmasoff
(Water Well Contractor)
Contractor's License No. 410 Date 3/21/67 19