

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
JAN 17 1963
STATE ENGINEER
SALEM OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

Linn
5333

State Well No. 10/4W-12H

G 2765

State Permit No.

(1) OWNER:

Name Gordon Hoefar #6
 Address Rt. 2 Box 146
ALBANY OREGON

(2) LOCATION OF WELL:

County LINN Driller's well number
~~Section 7 T. 10 S. R. 3 W. W.M.~~
 Bearing and distance from section or subdivision corner
SE 1/4 of NE 1/4, S. 12, T. 10 S, R. 4 W.
0° 45' W. 45.3 CHAINS FROM SE CORNER S. 12

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from 1 ft. to 29 1/2 ft. Gage 350
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used torch
 Size of perforations 1/4 x 3/8 in. by _____ in.
2 perforations from 2.3 ft. to 27 1/2 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name X
 Type X Model No. X
X Slot size X Set from X ft. to X ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Clay + Sand
 Depth of seal 16 ft. Was a packer used?
 Diameter of well bore to bottom of seal _____ in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from X ft. to X ft. X
 Did any strata contain unusable water? Yes No
 Type of water? River Depth of strata 18 Feet
 Method of sealing strata off

(10) WATER LEVELS:

Static level 13 ft. below land surface Date 3-21-63
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 600 gal./min. with 10 ft. drawdown after 2 hrs.
 " " " " "
 " " " " "
 Baller test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12"
 Depth drilled 32 ft. Depth of completed well 32 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface + Clay	0	6
CLEAN Gravel	6	18
1/2 layer of sand + clay	18	19
CLEAN Gravel	19	29
Clay / Brown	29	32

Work started 3-20 1963 Completed 3-21 1963
 Date well drilling machine moved off of well 3-21 1963

(13) PUMP:

Manufacturer's Name JAEZZI
 Type: CENTRIFUGAL H.P. 40

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Acc Drilling Co. (Type or print)
 Address Albany Oregon
 Drilling Machine Operator's License No. 52
 [Signed] Bill Hamilton (Water Well Contractor)
 Contractor's License No. 85 Date 3-22-63