

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED
MAR 5 1969
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

State Well No. _____
State Permit No. _____

(1) OWNER:
Name Howard Atkinson

Address Rt 3, Box 750
Albany, Ore 97511

(2) LOCATION OF WELL:
County Linn Driller's well number _____

1/4 Section T. R. W. 1/4
bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
10" Diam. from 1 ft. to 32 ft. Gage 30.7
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used Acetylene cutting torch
Size of perforations 1/2 to 3/4 in. by 10 in.
14 perforations from 24 ft. to 32 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION: Well seal - Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? no
Diameter of well bore to bottom of seal 17 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 20 ft. below land surface Date 4/2/69
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hr.

Ballier test 80 gal./min. with 120 ft. drawdown after 1 1/2 hr.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 39 ft. Depth of completed well 29

Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material of each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>loose brown</u>	<u>0</u>	<u>11</u>
<u>medium sand pebbles mixed</u>	<u>11</u>	<u>31 1/2</u>
<u>Blue clay</u>	<u>31 1/2</u>	<u>39</u>

Work started 5/30 1969 Completed 6/2 1969
Date well drilling machine moved off of well 6/4 1969

(13) PUMP: Manufacturer's Name _____
Type: _____ HP

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief.
NAME FRANK WACY WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 2431 PINE LANE, ALBANY
Drilling Machine Operator's License No. 364

[Signed] _____ (Water Well Contractor)
Contractor's License No. 423 Date 6/8 1969