NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

LINN 60800

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Linn 60800

State Well No. 10S/2W-13
State Permit No.

RECEIVED SEP - 2 1975 WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER:
Name O.P. AKIN
Address Rt. 2 Box 296 Jefferson

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 30 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations 3/16 in. by 6 in.
20 perforations from 22 ft. to 28 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 11 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County LINN Driller's well number 94
SE ¼ NE ¼ Section 13 T. 10S R. 2W W.M.
Bearing and distance from section or subdivision corner
950' NORTH 77' west from the SE corner of the SE 1/4

(11) WATER LEVEL: Completed well.
Depth at which water was first found 12 ft.
Static level 7 ft. below land surface. Date July 16, 75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 30 ft. Depth of completed well 30 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
BROWN SANDY soil + GRAVEL	0	12	
SAND + large GRAVEL	12	30	

Work started July 14 1975 Completed July 16 1975
Date well drilling machine moved off of well July 16 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Pat Riddors (Drilling Machine Operator) Date July 18, 1975
Drilling Machine Operator's License No. 898

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name FRANK WAGY WELL DRILLING (Person, firm or corporation) (Type or print)
Address 2435 Pine Lane Albany Ore.
[Signed] Frank Wagy (Water Well Contractor)
Contractor's License No. 423 Date 8-25, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119