NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

LINN 6083

Linn 60837

WATER WELL REPORT
STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED JUL 8 1975 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 10S/2W-3

State Permit No.

(1) OWNER:

Name Nestor Castillo

Address Rt. 2 Box 243 Albany, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 30 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.

Type of perforator used Tourch

Size of perforations 3/16 in. by 6 in.

20 perforations from 22 ft. to 28 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 30 gal./min. with 3 ft. drawdown after 2 hrs.

Artesian flow g.p.m.

Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Portland Cement

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 5 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Linn Driller's well number 91

SW ¼ NW ¼ Section 3 T. 10S R. 2W W.M.

Bearing and distance from section or subdivision corner

1800 ft. N, 95' E of the SW Corner of the N.W. ¼

(11) WATER LEVEL: Completed well.

Depth at which water was first found 19 ft.

Static level 13 ft. below land surface. Date 6/21/75

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing

Depth drilled 30 ft. Depth of completed well 30 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brown sandy soil	0	6	
Large Cobble Rock & sand	6	22	
Medium gravel & sand	22	30	

Work started 6/20/75 19 Completed 6/21/75 19

Date well drilling machine moved off of well 6/21/75 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Pat Kidder (Drilling Machine Operator) Date 6/22/75 19

Drilling Machine Operator's License No. 898

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Frank Wagy Well Drilling (Person, firm or corporation) (Type or print)

Address 2455 Pinehurst Albany Oregon

[Signed] Frank Wagy (Water Well Contractor)

Contractor's License No. [redacted] Date 7-4, 19 75

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119