

RECEIVED

JUL 1 1966

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

Linn 4099 60860

WATER WELL REPORT STATE ENGINEER OREGON (Please type or print)

State Well No. 10/2w-10R State Permit No.

(1) OWNER:

Name Wayne Staats Address Rte. #2 Seio, Ore.

(2) LOCATION OF WELL:

County Linn Driller's well number 181 SE 1/4 SE 1/4 Section 10 T. 10S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded [] Welded [x] 8" Diam. from 0 ft. to 70 ft. Gage .250

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Mills Size of perforations 1/2 in. by 2 in. 500 perforations from 70 ft. to 26 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite-Puddled clay Depth of seal 26 ft. Was a packer used? no Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 17 ft. below land surface Date 6/27/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Baller test 50 gal./min. with 6 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 71 ft. Depth of completed well 71 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil, Cement gravel, Clay-gravel, Silted gravel w.b., Clay-gravel (hard), Clay-gravel (soft-brown), Clay-gravel (soft-green), Cement gravel, Silted gravel w.b., River gravel-sand (silted) water bearing, Sand and clay (hard packed).

Work started 6/22/66 19 Completed 6/27/66 19 Date well drilling machine moved off of well 6/27/66 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kate Tolmesoff Well Drilling (Person, firm or corporation) (Type or print)

Address Turner, Ore.

Drilling Machine Operator's License No. 320

[Signed] Kate Tolmesoff (Water Well Contractor)

Contractor's License No. 418 Date 6/30/66 19