NOTICE TO WATER WELL CONTRACTOR 1180 of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Do not write above this line)

(1) OWNER:	(10) LOCATION OF WELL:
Name Robert Houston	County Linn Driller's well number
Address 1920 Thurston St., Albany, Ore. 97321	14 14 Section 9 T. 11S R. 2W W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well	
If abandonment, describe material and procedure in Item 12.	
	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 18 ft.
Cable Jetted	Static level 10 ft. below land surface. Date 2-15-73
Bored Irrigation K Test Well Other	Artesian pressurelbs. per square inch. Date
(5) CASING INSTALLED: Threaded □ Welded □X	(12) WELL LOG: Diameter of well below casing
10" Diam. from +08!! ft. to 34104!! ft. Gage 250Wall	Depth drilled 35 ft. Depth of completed well 35 ft.
ft. Gageft.	Formation: Describe color, texture, grain size and structure of materials;
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated,
(6) PERFORATIONS: Perforated? Ty Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
(6) PERFURATIONS: Perforated? XYes \(\square\) No. Type of perforator used \(\text{Acetylene Torch} \)	MATERIAL From To SWL
Size of perforations ½ in. by 12 in.	Top Soil 0 2
60 perforations from 22 ft. to 34 ft.	Loam 2 12
perforations from ft. to ft.	Clay & Gravel 12 15
perforations fromft. toft.	Dirty Gravel 15 18
/#/ CODDINA.	Brown Sand & Gravel 18 32
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	Brown Clay & Gravel 32 35
Manufacturer's Name Model No.	
Diam. Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes V No If yes, by whom?	
gal./min. with ft. drawdown after hrs.	
$n = \frac{n^{-1}}{n}$	
n	
Bailer test 130 gal./min. with NO ft. drawdown after 1½ hrs.	
sian flow g.p.m.	
Temperature of water Depth artesian flow encountered ft.	Work started 2-13 19 73 Completed 2-15 19 73
(9) CONSTRUCTION:	Date well drilling machine moved off of well 2- 15 19 73
	Drilling Machine Operator's Certification:
Well seal—Material used <u>Bentonite</u> Well sealed from land surface to <u>18</u> ft.	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal 14 in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Date Date (Drilling Machine Operator)
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No.
Brand name of bentonite Oregon Bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals. Was a drive shoe used? Yes No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	Name Merle Warren Well Drilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Rt. 1, Box 84, Tangent, Ore. 97389
Method of sealing strata off	Mark Illan
Was well gravel packed? Yes \ No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 182 Date 8/17, 19.73
GLAYOL PIACCU HUIH II. W II.	DELUCION D LICCARDO ATO: DELUCIO DE DE CONTROL DE LO CONTROL DE LA CONTR