

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

RECEIVED MAY 17 1967

WATER WELL REPORT

STATE ENGINEER SALEM, OREGON

(Please type or print)

LI NN 6687

State Well No. 11/2w-15L

State Permit No.

G-4042

(1) OWNER:

Name ELMER L. PERRY Address RT 1 - Box 311 ALBANY ORE.

(2) LOCATION OF WELL:

County LINN Driller's well number 1/4 Section 15 T. 11 R. 2 W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Drill Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

10" Diam. from 1 ft. to 28 ft. Gage 350

(7) PERFORATIONS:

Perforated? [x] Yes [ ] No Type of perforator used TORCH Size of perforations 5 in. by 6 in. 64 perforations from 18 ft. to 28 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE Depth of seal 18 ft. Was a packer used? NO Diameter of well bore to bottom of seal 14 in. Were any loose strata cemented off? [ ] Yes [x] No Depth Was a drive shoe used? [x] Yes [ ] No Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 3-11-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? CUSTOMER Yield: 300 gal./min. with 1/2 ft. drawdown after 2 hrs.

(12) WELL LOG:

Diameter of well below casing 10 Depth drilled 28 ft. Depth of completed well 28 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Contains handwritten entries: BROWN SANDY CLAY (0 to 8 1/2), UNCONSOLIDATED SAND & GRAVEL TO COBBLES (8 1/2 to 28), SIZE WITH HIGH PERCENT OF SAND & REDDISH SILT.

Work started 3-9-67 19 Completed 3-10-67 19 Date well drilling machine moved off of well 11-18-19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Robinson & West (Person, firm or corporation) (Type or print) Address 5545 DuSoyne St. S.E. Drilling Machine Operator's License No. 188 [Signed] Hudson R. Miller (Water Well Contractor) Contractor's License No. 37 Date 3-11-67, 19