NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

513
8-LINN
6745

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
SEP 27 1973
STATE ENGINEER
SALEM, OREGON

State Well No. 11S/2W-20 dd
State Permit No.

(1) OWNER:
Name Sam Allen
Address Route #2 Box 482 EC
Lebanon, Oregon 97355

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED: Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 53 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? [X] Yes [ ] No.
Type of perforator used Torch
Size of perforations 3/16 in. by 6 in.
20 perforations from 44 ft. to 51 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 60 gal./min. with 17 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 57 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 34 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Linn Driller's well number 183973J
SE ¼ SE ¼ Section 20 T. 11S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 10 ft.
Static level 10 ft. below land surface. Date 9-7-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 52 ft. Depth of completed well 52 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	2	
Sand and gravle	2	29	10
Sandy brown clay	29	35	
Coarse brown sand and small gravel	35	52	

Work started 9-6 19 73 Completed 9-7 19 73
Date well drilling machine moved off of well 9-7 19 73

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Joe Babcock (Drilling Machine Operator) Date 9-21, 1973
Drilling Machine Operator's License No. 382

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric and Pump (Person, firm or corporation) (Type or print)
Address 626 W. Queen/Albany, Oregon 97321
[Signed] Lamy E Schoen (Water Well Contractor)
Contractor's License No. 513 Date 9/24, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119