

RECEIVED
MAY 29 1961

LINN
6998

11/2w-35D

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. _____

State Permit No. _____

(1) OWNER:
Name ROBERT F. MEYER
Address 490 SEVENTH ST.
LEBANON, OREGON

(2) LOCATION OF WELL:
County LINN Owner's number, if any—
NW 1/4 NW 1/4 Section 35 T. 11 R. 2 W W.M.
Bearing and distance from section or subdivision corner
S. 15° 15' CHAINS FROM NW CORNER
OF S. 35, T. 11 S, R. 2 W. W.M.

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
12" Diam. from 10" ft. to 26 1/2" ft. Gages 350
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Type of perforator used shots
Perforated? Yes No
SIZE of perforations 3/4 in. by 10 in.
35 perforations from 20 ft. to 26 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain upusable water? Yes No
Type of water? RIVER Depth of strata 27
Method of sealing strata off

(10) WATER LEVELS:
Static level 10 ft. below land surface Date 4-28-61
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
[Signed] Robert F Meyer Date April 29, 1961
(Owner)

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 500 gal./min. with 7 ft. drawdown after 2 hrs.
" " " " " " " "
" " " " " " " "
" " " " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:
Diameter of well 12 inches.
Depth drilled 27 ft. Depth of completed well 27 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface + Clay	0	4
2" of gravel + clay	4	10
Very large gravel	10	27
Some sand	10	27
large gravel + clay		
Mixed	27	27

Work started 4-25 1961 Completed 4-28 1961

(13) PUMP:
Manufacturer's Name _____
Type: 2" CENTRIFUGAL H.P. 10

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Acc Drilling Co.
(Person, firm, or corporation) (Type or print)
Address 838 E 3rd Ave
Driller's well number # 1
[Signed] Bill Hamilton
(Well Driller)
License No. 52 Date 4-28, 1961