

RECEIVED
NOV 17 1958

LINN
7003

1 1/2 W - 35 J (1)

STATE ENGINEER WATER WELL REPORT

SALEM, OREGON STATE OF OREGON

G1260

State Well No.

State Permit No.

G1083

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: H. G. Christenson
Name H. G. Christenson
Address Route # 2 Box 243 E
Lebanon Oregon

(2) LOCATION OF WELL:
County Linn Owner's number, if any—1083
NE 1/4 SE 1/4 Section 35 T. 115 R. 2 W. W.M.
Bearing and distance from section or subdivision corner 1099 ft
South 7 257 5 ft West from
NE corner of Andrews Reel DLC
6 T. 115 R. 2 W. W. North E 1/4 off
E 1/4 sec 35 T. 115 R. 2 W

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
10" Diam. from ft. to casing ft. Gage double
....." Diam. from ft. to 25' ft. Gage
....." Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Type of perforator used slots
Perforated? Yes No
SIZE of perforations 1/2 in. by 8 in.
15' perforations from ft. to 25' ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
..... Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 25 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Date, 19.....
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " " "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 10" inches.
Depth drilled 30' ft. Depth of completed well 30' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>sandy loam</u>	<u>12'</u>	
<u>river gravel</u>	<u>12' 30'</u>	
<u>clay</u>	<u>30'</u>	

Work started before Oct 19 46 Completed same 19.....

(13) PUMP:
Manufacturer's Name Universal Centrifical
Type: shallow well pump H.P. 15

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME I do not know as I
(Person, firm or corporation) (Type or print)
Address did not own place at
Driller's well number that time

[Signed] (Well Driller)
License No. Date, 19.....