NC

NOTICE TO WATER WELL CONTRACTOR

The original and first copy was well water well report of this report are to be filed with the water wate

1090

G-4036

3 年 State Well No. /1/3 いー号

STATE ENGINEER, SALEM, OREGON 97310 (Please type or print) within 30 days from the date TIL ENGINEER (Do not write above this line) of well completion. SALEM, OREGON

State Permit No.

1) OWNER:	(11) LOCATION OF WELL:
Name Charles Karnosh	County Linn Driller's well number
Address Clover Ridge Road, Albany, Oregon	14 14 Section 4 T. 11S R. 3W W.M.
(a) MYDE OF WORK (about)	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Welly Deepening	
f abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Rotary Driven Domestic Industrial Municipal Domestic Industrial Municipal	Depth drilled 65 ft. Depth of completed well 65 ft.
Oug 🗌 Bored 🗍 Irrigation 🧣 Test Well 🗍 Other 🗍	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded   Welded	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change
	In position of Static Water Level as drilling proceeds. Note drilling rates.
	MATERIAL From To SWL
ft. Gageft.	Top Soil 0 1
DEDECO ATTIONS.	Black Clay 1 4
PERFORATIONS: Perforated 2 Yes No.	Brown Clay 4 9
Type of perforator used Acetylene Torch	Clay & Boulders 9 26
Size of perforations 1/2 in. by 12 in.	Brown Sand & Gravel 26 33
36 perforations from51 ft. to63 ft.	Brown Clay 33 36
perforations from ft. to ft.	Blue Clay 36 /18
perforations from ft. to ft.	Blue Clay & Gravel 48 51
perforations from ft. to ft.	Black Sand & Gravel 51 65
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes XNo	
Manufacturer's Name	
Type Model No.	
Diam Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(0) WAMED LEVEL. Completed well	
(8) WATER LEVEL: Completed well.	
Static level 12103!! ft. below land surface Date 8-4-67	
sian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made?   Yes X No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	Work started 7-25 19 67 Completed 8-4 19 67
" " "	Date well drilling machine moved off of well 8-4 1967
" " " "	Drilling Machine Operator's Certification:
Bailer test 90 gal./min. with 12 ft. drawdown after 1 hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
	[Signed] Markin Marse Date 8-8, 1967
Temperature of water Was a chemical analysis made? ☐ Yes X☐ No	(Drilling Machine Operator)
(10) CONSTRUCTION:	Drilling Machine Operator's License No. 436
Well seal—Material usedBentonite	
Depth of sealft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal 12 in.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Were any loose strata cemented off?   Yes No Depth	•
Was a drive shoe used? ∑ Yes □ No	NAME Merle Warren Well Drilling (Type or print)
Did any strata contain unusable water?  Yes No	Address Pt. 1, Box 85, Tangent, Oregon
Type of water? depth of strata	March 111-11
Method of sealing strata off	[Signed] / flile Warren
Was well gravel packed? ☐ Yes 📉 No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 182 Date 194