NOTICE TO WATER WELL CONTRACTOR The original and first cooper of this report are to be MAY 1 1 1972 WATER WELL REPORT STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310 ENGINE THE OF OREGON within 30 days from the date A LE ENGINEERS type or print)

of well completion. SALEM OR So not write a	bove this line) State Permit N	fo	
(1) OWNER:	(10) LOCATION OF WELL:		
Name Walter Underwood	* •		
Address 3532 Dunlap Ave., Albany, Ore. 97321		***********	
	½ ½ Section 4 T. 11S	70	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivis	on corner	
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐		The same Standing	
If abandonment, describe material and procedure in Item 12.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed w	rell.	
Peters D. Prima D.		-6 <u>ft.</u>	
Cable I Jetted Domestic I Industrial Municipal	Static level 12 ft. below land:	surface. Date 5-3-72	
Dug	Artesian pressure lbs. per squar	re inch. Date	
CASING INSTALLED: Threaded Welded	(19) WELL LOC.		
6" Diam. from	(12) WELL LOG: Diameter of well below casing 6!! Depth drilled 80 ft Depth of completed well 80 ft		
" Diam. from ft. to ft. Gage	Depth drilled OO ft. Depth of compl	leted well 80 ft.	
	Formation: Describe color, texture, grain size	and structure of materials;	
THE TOTAL METAL STATE OF THE TAXABLE PROPERTY OF T	and show thickness and nature of each stratus with at least one entry for each change of forma	tion. Report each change in	
PERFORATIONS: Perforated? Yes I No.	position of Static Water Level and indicate prin	cipal water-bearing strata.	
Type of perforator used Acetylene Torch	MATERIAL	From To SWL	
Size of perforations 3/8 in. by 12 in.	Top Soil	0 2	
	Brown Clay	2 3	
perforations from ft. to ft.	Brown Clay & Gravel	3 18	
perforations from ft. to ft.	- Dirty Gravel	18 23 .	
(7) SCREENS: Well screen installed? ves X No	Brown Clay & Gravel	23 32	
Manufacturer's Name	Brown Clay	32 40	
Type Model No.	Blue Clay	40 43	
Diam. Slot size Set from ft. to ft.	Blue Clay & Gravel	43 46	
Diam. Slot size Set from ft. to ft.	Black Sand & Gravel	46 53	
(8) WELL TESTS: Drawdown is amount water level is	Black Sandy Clay Black Sand & Gravel	53 65	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Black Clay & Gravel	65 78	
Was a pump test made? ☐ Yes ☑ No If yes, by whom?	Track Cray & Graver	70 00	
Yield: gal./min. with ft. drawdown after hrs.			
" " " " " " " " " " " " " " " " " " " "			
" " "			
Bailer test 70 gal./min. with 71/2 ft. drawdown after 11/2 hrs.			
Artesian flow g.p.m.		- - - - - - - - - - 	
perature of water Depth artesian flow encountered ft.	Waste standard and a second se		
	Work started 4-28 1972 Completed 5-3 1972		
(9) CONSTRUCTION:	Date well drilling machine moved off of well 5-3 1972		
Well seal—Material used Bentonite	Drilling Machine Operator's Certification:		
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my		
Diameter of well bore to bottom of sealin.	best knowledge and belief.		
Diameter of well bore below seal in.	[Signed] (Drilling Machine Operator) Date , 19		
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No. 436		
Number of sacks of bentonite used in well seal 4 sacks	Drining Machine Operator's License 100.		
Brand name of bentonite <u>Oregon Bentonite</u> Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is		
Was a drive shoe used? Yes \(\subseteq No \) Plugs Size: locationft.	true to the best of my knowledge and belief.		
Did any strata contain unusable water? Yes A No	Name Merle Warren Well Drilling		
Type of water? depth of strata	(Person, firm or corporation) (Type or print) Address Rt. 1. Box 84. Tangent. Ore. 97389		
Method of sealing strata off	Address Livera DOA OT, Tangent, Ore, 9/389		
77	[Signed] [Mill] [Marre	m/	
Was well gravel packed? Yes No Size of gravel:	(Water Well Contra	James James James	
Gravel placed from ft. to ft.	Contractor's License No. 182 Date	5/4, 19/2	