RECEIVED
SEP 8 1960
STATE ENGINEER
SALEM, OREGON

LINN 7227

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 11/3w-8

State Permit No.

(1) OWNER:

Name Reorganized Church of Jesus Christ of the ~~xxxxxx~~ Latter Day Saints

2526 20th Street, Albany, Oregon

(2) LOCATION OF WELL:

County Linn Owner's number, if any—

¼ ¼ Section 8 T. 11 S. R. 3 W. W.M.

Bearing and distance from section or subdivision corner

180 ft. South and 160 ft. West of East ~~xxxxxxx~~ section corner.

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐

Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐

Cable ☒ Jetted ☐

Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 56 ft. Gage 17

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used torch

SIZE of perforations ¼ in. by 6 in.

20 perforations from 51 ft. to 55 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Was a surface seal provided? ☐ Yes ☒ No To what depth? ft.

Material used in seal—

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? Depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date

Artesian pressure lbs. per square inch Date

Log Accepted by:

PASTOR [Signed] Eldon D. Slover [Owner] Date Sept. 5, 1960

Rt. 4, Box 206
Albany, Oregon

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 20 gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well 6 inches.

Depth drilled 56 ft. Depth of completed well 56 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil	0'	2'
Clay	2'	15'
Hard pan	15'	51'
Gravel	51'	56'

Work started Aug. 16 1960 Completed Aug. 20 1960

(13) PUMP:

Manufacturer's Name

Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME N. Klaus Drilling Co. (Person, firm, or corporation) (Type or print)

Address Rt. 4, Box 35-X, Albany, Oregon

Driller's well number

[Signed] Nicholas Klaus (Well Driller)

License No. 269 Date Aug. 30, 1960

(USE ADDITIONAL SHEETS IF NECESSARY)