

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
FEB - 8 1973
STATE OF OREGON
STATE ENGINEER
SALEM, OREGON
(Please type or print)
(Do not write above this line)

LINN
7417

State Well No. 11S/3W-21 *aa*
State Permit No. _____

STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

(1) OWNER:

Name Dick Draper / Amigo Acres
Address 1904 South Main
Albany, Oregon 97321

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 192 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills Knife
Size of perforations 1/4 in. by 4 in.
132 perforations from 139 ft. to 188 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test 80 gal./min. with 5 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 86 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 54 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Linn Driller's well number 8173B
NE 1/4 NE 1/4 Section 21 T. 11S R. 3W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 18 ft.
Static level 5 ft. below land surface. Date 1-29-73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	1	
Clay (Brown)	1	18	
Sand and Gravel	18	39	20
Sand	39	41	
Sand and Gravel	41	51	
Clay (Brown)	51	63	
Sand and Gravel	63	66	
Clay (Gray)	66	80	
Clay (Green)	80	94	
Sand (Black)	94	95	
Clay (Gray)	95	103	
Clay (Dark Gray)	103	119	
Sand (Black)	119	127	5
Sand and Gravel	127	190	
Clay (Gray)	190	200	

Work started 1-11 1973 Completed 1-29 1973
Date well drilling machine moved off of well 1-29 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] W.A. Sambella Date 1/31, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 491

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric and Pump
(Person, firm or corporation) (Type or print)
Address 626 W. Queen / Albany, Oregon 97321
[Signed] Larry E. Schoen
(Water Well Contractor)
Contractor's License No. 513 Date 1/30 1973