

RECEIVED
MAY 18 1959
STATE ENGINEER

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
7481
G-4482

State Well No. 11/3W-27 C
State Permit No. _____

(1) OWNER:

Name Daniel D. Widmer
Address Route 1, Box 392
Albany, Oregon

(2) LOCATION OF WELL:

County Linn Owner's number, if any—
pt. NE ¼ Section 27 T. 11S R. 3W W.M.
Bearing and distance from section or subdivision corner
Property lying West of the County Road.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 1 ft. to 90'7" ft. Gage 17
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used torch
SIZE of perforations $\frac{1}{4}$ in. by 10 in. long
20 perforations from 79'7" ft. to 90'7" ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
" _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 4/30/59
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] D. D. Widmer Date May 1, 1959
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " "

Bailer test XX gal./min. with 40 ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 111½ ft. Depth of completed well 111½ ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top soil	0'	2'
clay	2'	20'
gravel	20'	26'
sandstone	26'	38'
clay, white	38'	68'
clay, blue	68'	90'
sandstone	90'	108'
gravel	108'	111½'

Work started 4/20 19 59 Completed 4/30 19 59

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME N. Klaus Drilling Co.
(Person, firm, or corporation) (Type or print)
Address Rt. 4, Box 345-X, Albany, Ore.
Driller's well number _____
[Signed] Frank D. Wang
(Well Driller)
License No. 270 Date May 1, 1959