

**(1) OWNER:**

Name Doug James  
Address 2350 South Marion  
Albany, Oregon 97321

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL: (4) PROPOSED USE (check):**

Rotary <input type="checkbox"/>	Driven <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Industrial <input type="checkbox"/>	Municipal <input type="checkbox"/>
Cable <input checked="" type="checkbox"/>	Jetted <input type="checkbox"/>	Irrigation <input type="checkbox"/>	Test Well <input type="checkbox"/>	Other <input type="checkbox"/>
Dug <input type="checkbox"/>	Bored <input type="checkbox"/>			

**(5) CASING INSTALLED:** Threaded  Welded

6 " Diam. from 0 ft. to 64 ft. Gage .250  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

**(6) PERFORATIONS:** Perforated?  Yes  No.

Type of perforator used Torch  
Size of perforations 3/16 in. by 6 in.  
16 perforations from 57 ft. to 63 ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

**(7) SCREENS:** Well screen installed?  Yes  No

Manufacturer's Name .....  
Type ..... Model No. ....  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " " " " " " " "  
" " " " " " " " " " " "  
Bailer test 60 gal./min. with 10 ft. drawdown after 2 hrs.  
Artesian flow g.p.m. ....  
Temperature of water 57 Depth artesian flow encountered ..... ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 3 sacks  
Number of sacks of bentonite used in well seal ..... sacks  
Brand name of bentonite .....  
Number of pounds of bentonite per 100 gallons  
of water ..... lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? ..... depth of strata .....  
Method of sealing strata off .....  
Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL:**

County Linn Driller's well number 194973J  
NW ¼ NW ¼ Section 28 T. 11S R. 3W W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 18 ft.  
Static level 15 ft. below land surface. Date 9-24-73  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:** Diameter of well below casing 6"

Depth drilled 66 ft. Depth of completed well 66 ft.  
Formation: Describe color, texture, grain size and structure of materials;  
and show thickness and nature of each stratum and aquifer penetrated,  
with at least one entry for each change of formation. Report each change in  
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	18	15
Dirt and gravel	18	25	
Sand and small gravel	25	45	
Sand and large gravel	45	63	
Brown clay	63	66	

Work started 9-24 1973 Completed 9-24 1973  
Date well drilling machine moved off of well 9-24 1973

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Joe Belovich Date 9-28, 1973  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 382

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Schoen Electric and Pump (Type or print)  
(Person, firm or corporation)  
Address 626 W. Queen/Albany, Oregon 97321  
[Signed] Larry E. Schoen (Water Well Contractor)  
Contractor's License No. 513 Date 9/28, 1973