

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

JUL 16 1965

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER

State Well No.

11/3w-28C

State Permit No.

(1) OWNER: SALEM, OREGON

Name Merlin Foster
Address Route 3 Box 1106
ALBANY OREGON

(2) LOCATION OF WELL:

County Linn Driller's well number 11
NE 1/4 NW 1/4 Section 28 T. 11S R. 3W W.M.
Bearing and distance from section or subdivision corner 257 ft
West from north east corner.
22 feet south of north line.

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]

8" Diam. from +1 ft. to 64 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [] No

Type of perforator used Acetylene Cutting Torch
Size of perforations 3/8 in. by 10 in.
18 perforations from 64 ft. to 54 ft.
20 perforations from 44 ft. to 24 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [X] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 5 ft. below land surface Date 6/15/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Frank Way
Yield: 50 gal./min. with 17 ft. drawdown after 2 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 8 inch.

Depth drilled 66 ft. Depth of completed well 66 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include BROWN Top Soil, BROWN DIRT, BROWN DIRT with some Rock, Pea gravel-Black coarse, SAND + some ROCK, Blue SAND AND Pea gravel.

Work started 6/6 1965. Completed 6/15 1965
Date well drilling machine moved off of well 6/15 1965

(13) PUMP:

Manufacturer's Name Pierce
Type: Turbine H.P. 7.5

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME FRANK Way-Well Drilling
Address 2435 Pine Lane ALBANY Ore
Drilling Machine Operator's License No. 364
[Signed] Frank Way
Contractor's License No. 423 Date 6/22, 1965