

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

RECEIVED

OCT - 2 1986

Linn
7758

125/2W-10

(1) OWNER:
 Name LEBANON PUBLIC SCHOOLS Owner's Well Number WATER RESOURCES DEPT
 Address GREEN ACRES SCHOOL 10th & SHERMAN DISSEMIN, OREGON
 City LEBANON State ORE Zip 97355

(9) LOCATION OF WELL by legal description:
 County LINN Latitude _____ Longitude _____
 Township 12 SOUTH N or S, Range 2 WEST E or W, WM.
 Section 10 1/4 1/4
 Tax Lot 600 Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) _____

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(5) BORE HOLE CONSTRUCTION:
 Depth of Completed Well 106' ft.
 Special Standards date of approval _____

HOLE meter	From	To	SEAL		Amount sacks or pounds	
			Material	To		
2	0	34	CEMENT	0	34	22 SACKS

How was seal placed? Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:	8	+1/2	106	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

location of shoe(s) _____

(7) PERFORATIONS/SCREENS:

Perforations Method TORCH
 Screens Type _____ Material _____

mm	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
16	103	3/16 x 6	35			<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Yield gal/min	Pumping level	Drill stem at	Time
80	20'		1/2 hr
90	22'		1 hr
90	22'		4 HRS

Temperature of water 54° Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: _____

(10) STATIC WATER LEVEL:
14 ft. below land surface. Date 9-4-86
 Artesian pressure _____ lb. per square inch. Date _____

(11) WELL LOG: Ground elevation _____

Material	From	To	WB?	SWL
TOP SOIL	0	2		
LOAM	2	8		
CLAY-BROWN w/GRIT	8	27		
CLAY-BROWN w/GRIT GRAY	27	36		
CLAY-BROWN-SILTY	36	48		
SAND w/CLAY SILTY	48	60		
CLAY-BROWN w/GRIT	60	74		
CLAY-GRAY w/GRIT	74	82		
SAND & GRAVEL-SILTY	82	90		
SAND COARSE	90	95	X	14'
SAND & GRAVEL	95	106	X	14'
CLAY-BROWN w/GRAVEL	106	108		

Date started 8-28-86 Completed 9-5-86

(unbonded) Water Well Constructor Certification:
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
 Signed _____ Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.
 Signed Charles D. Nugent Date 9-6-86
 Company NUGENT Drilling Co. Job No. DR-400