

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED

APR - 2 1963

WATER WELL REPORT

STATE OF OREGON (Please type or print)

SALEM, OREGON

State Well No. 12/2W-20

State Permit No.

(1) OWNER:

Name Arthur Swanson
Address Rt 2, Box 110
Lebanon Oregon.

(2) LOCATION OF WELL:

County Linn Driller's well number
1/4 1/4 Section 20 T. 12 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐
Irrigation ☐ Test Well ☐ Other ☐ Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 60 ft. Gage 280
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 45 ft. Was a packer used? gravel
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 33 ft. below land surface Date 3-25-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Baller test 1000 gal./min. with all ft. drawdown after 2 hrs.

Artesian flow g.p.m. Date

Temperature of water 52 Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 135 ft. Depth of completed well 135 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY SOIL	0	3
BLACK SOIL	3	12
YELLOW CLAY	12	18
hard blue SANDSTONE	18	45
light blue SANDSTONE	45	60
hard	60	135

Water Strata 61',
71',
128'

Work started 3-18 19 63 Completed 3-25 19 63
Date well drilling machine moved off of well 3-27 19 63

(13) PUMP:

Manufacturer's Name Fairbanks Morse
Type: Submersible H.P. 1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Willamette Irrigation & Equip Co
(Person, firm or corporation) (Type or print)

Address Star Route #2, Box 5, Lebanon

Drilling Machine Operator's License No. 31

[Signed] Carl H Saunders
(Water Well Contractor)

Contractor's License No. 49 Date 3-28, 19 63