

ORIGINAL
File Original and Duplicate with the STATE ENGINEER, SALEM, OREGON

RECEIVED WATER WELL REPORT
DEC. 4 1957 STATE OF OREGON G679

State Well No. 11/4W-11F(2)
State Permit No. 6592

(1) OWNER: STATE ENGINEER
SALEM, OREGON
Name Heyman-Campbell Farms
Address Rt. 3, Box 668 Albany, Oregon *LINN \$303*

(2) LOCATION OF WELL:
County Linn Owner's number, if any 592
SE ¼ NW ¼ Section 11 T. 11S R. 4W W.M.
Bearing and distance from section or subdivision corner
N. 43° 35' W. 8.8 chains from the NE corner of John Layton DLC No. 57, T 11 S, R. 4 W.

TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Agricultural Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
10" Diam. from 0 ft. to 37 ft. Gage 22#
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:
Type of perforator used Acetylene torch
SIZE of perforations 3/8 in. by 12 in.
7 perforations from 23 ft. to 37 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

SCREENS: Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 21 ½ ft. below land surface Date 11-15-57
Artesian pressure _____ lbs. per square inch Date _____
Log Accepted by: Heyman-Campbell Farms
(Signed) _____ Date 11-22, 1957
By Ed Heyman
(Owner)

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Heyman
Yield: 200 gal./min. with 2 ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 10 inches.
Depth drilled 42 ft. Depth of completed well 41 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	4
Sand	4	18
Gravel	18	36
Blue clay	36	42

Work started 11-12 1957 Completed 11-15 1957

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Merle E. Warren, Well Drilling
(Person, firm, or corporation) (Type or print)
Address 1315 W. 15th Ave., Albany, Oregon
Driller's well number _____
[Signed] Merle Warren
(Well Driller)
License No. 182 Date 11/21, 1957