

WATER WELL REPORT

STATE OF OREGON JUL 17 1975

(Please type or print)

WATER RESOURCES DEPT.

SALEM, OREGON

State Well No. 115/4W-14

State Permit No.

8342

(1) OWNER: G-7388
Name Ed Garrison
Address 2554 S. W. Oakville Road
Albany, Oregon 97321

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from 6 ft. to 0 ft. Gage 40
" Diam. from 0 ft. to 0 ft. Gage .250
" Diam. from 0 ft. to 0 ft. Gage

(7) PERFORATIONS:
Perforated? Yes No.
Type of perforator used mills knife
Size of perforations 3/8 in. by 4 in.
60 perforations from 22 ft. to 39 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 12 gal./min. with 75 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Linn Driller's well number 83675A
SW 1/4 NE 1/4 Section 14 T. 11S R. 4W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 12 ft. below land surface. Date 6-26-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 90 ft. Depth of completed well 90 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown clay	0	20	12'
sand & gravel	20	26	
sandy blue claystone	26	38	
blue claystone	38	56	
sandy blue claystone	57	60	
blue cl claystone	60	90	

Work started 6-24 1975 Completed 6-26 1975
Date well drilling machine moved off of well 6-26 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Alvin Handberg Date 7/16, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 652

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric & Pump (Person, firm or corporation) (Type or print)
Address 626 W. Queen Ave. Albany, Oregon 97321
[Signed] Larry E. Schoen (Water Well Contractor)
Contractor's License No. 513 Date 7/16, 1975