

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy  
 of this report are to be  
 filed with the

**RECEIVED**  
 JUL 26 1972

**WATER WELL REPORT**

STATE ENGINEER, SALEM, OREGON  
 within 30 days from the date  
 of well completion.

STATE OF OREGON  
 STATE ENGINEER  
 SALEM, OREGON  
 (Please type or print)  
 (Do not write above this line)

LINN  
 8643

State Well No. 11S/4W-31

State Permit No.

**(1) OWNER:**

Name DAVE COEN  
 Address 957 LAKE SHORE DR. CORVALLIS  
 address changed from card sent 7/10/72

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
 6" Diam. from 0 ft. to 38 ft. Gage 250  
 " Diam. from " ft. to " ft. Gage  
 " Diam. from " ft. to " ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.  
 Type of perforator used GAS TORCH  
 Size of perforations 7 in. by 10 in.  
 3 perforations from 3.6 ft. to 3.7 ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name  
 Type Model No.  
 Diam. Slot size Set from " ft. to " ft.  
 Diam. Slot size Set from " ft. to " ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 " " " " "  
 " " " " "  
 Bailer test 30 gal./min. with 9 ft. drawdown after 1 hrs.  
 Artesian flow g.p.m.  
 Temperature of water Depth artesian flow encountered " ft.

**(9) CONSTRUCTION:**

Well seal—Material used CEMENT  
 Well sealed from land surface to 18 ft.  
 Diameter of well bore to bottom of seal 9 in.  
 Diameter of well bore below seal 6 in.  
 Number of sacks of cement used in well seal 1 sacks  
 Number of sacks of bentonite used in well seal " sacks  
 Brand name of bentonite  
 Number of pounds of bentonite per 100 gallons  
 of water " lbs./100 gals.  
 Was a drive shoe used?  Yes  No Plugs " Size: location " ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off  
 Was well gravel packed?  Yes  No Size of gravel: " ft.  
 Gravel placed from " ft. to " ft.

**(10) LOCATION OF WELL:**

County LINN Driller's well number  
 1/4 1/4 Section 31 T.11 S R. 4 W.M.  
 Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 36 ft.  
 Static level 18 ft. below land surface. Date 7/11/72  
 Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing  
 Depth drilled 38 ft. Depth of completed well 38 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BROWN SANDY CLAY	0	24	
BROWN SAND & GRAVEL	24	27	
BROWN SAND	27	33	
BROWN SAND & GRAVEL	33	38	18

Work started 7/10/72 19 Completed 7/11/72 19  
 Date well drilling machine moved off of well 7/11/72 19

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] Bill Howell Date 7/19/72, 1972  
 (Drilling Machine Operator)  
 Drilling Machine Operator's License No. 79

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 Name Howell Well Drilling  
 (Person, firm or corporation) (Type or print)  
 Address 6915 S.W. Philomath Blvd. CORVALLIS  
 [Signed] Bill Howell  
 (Water Well Contractor)  
 Contractor's License No. 50 Date 7/19/72, 1972