

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED
JUN 13 1968
STATE ENGINEER
SALEM, OREGON

RECEIVED
AUG 19 1968
STATE ENGINEER
SALEM, OREGON

STATE ENGINEER, SALEM, OREGON 97301 (Please type or print)
within 30 days from the date of well completion. Do not write above this line.

Date Well No. 11/40-31
Permit No. _____

(1) OWNER:

Name Peterson, Edlin
Address 355 N.E. 33rd, Corvallis, Oregon

LINN
8053

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic ~~15~~ Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 31 ft. Gage STD
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

PERFORATIONS:

Perforated? Yes No
Type of perforator used acetylene
Size of perforations 6 in. by $\frac{1}{4}$ in.
25 perforations from 25 ft. to 30 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 16 ft. below land surface Date 5/31/68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with _____ ft. drawdown after _____ hrs.
" " " " "
" " " " "
Bailer test 15 gal./min. with 7 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 55 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used drilled with Bentonite
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Benton/Linn Driller's well number _____
 $\frac{1}{4}$ Section 31 T. 115 R. 4W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 31 ft. Depth of completed well 31 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
brown loam	0	2	
sandy loam	2	18	
coarse gravel	18	23	
gravel & sand	23	25	
Medium gravel baring water	25	31	

Work started 5/31/ 1968 Completed 5/31/ 1968
Date well drilling machine moved off of well 5/31/ 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ronald S. Witham Date 6/1/1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 503

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Raymond C. Gallatly & Ronald S. Witham
(Person, firm or corporation) (Type or print)

Address P.O. Box 1, Philomath, Oregon

[Signed] Raymond C. Gallatly
(Water Well Contractor)

Contractor's License No. 77 Date 6/1/1968