NOTICE TO WATER WELL CONTRACTOR		, i s mat Ca	
of this report are to be WATER WELL REPORTS F WE TO US/U/1-32			
filed with the STATE ENGINEER, SALEM, OREGON 97310	or print) JUN LY (3/)	and the second	
within 30 days from the date of well completion.	• CALLE ENGINE		
0011	SALEM OREGON	1	
(1) OWNER:	(10) LOCATION OF WELL:		
Name West Linn Water Co., Inc.	County Linn Driller's well nu	mber 76673B	
Address 4380 N. E. Westlinn Drive	NE 1/4 SW 1/4 Section 32 T. 11S	<u>в. 4W w.м.</u>	
Corvallis, Oregon 97330	Bearing and distance from section or subdivision corner		
(2) TYPE OF WORK (check):	ـــــــــــــــــــــــــــــــــــــ		
New Well 🕅 Deepening 🗌 Reconditioning 🗍 Abandon 🗌			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	<b>.</b>	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 21	ft.	
Rotary     Driven       Cable     XX       Jetted     Domestic   Industrial	Static level 23 ft. below land su	urface. Date5-30-73	
Dug 📋 Bored 🗌 Irrigation 🗋 Test Well 🗋 Other _ 🗋	Artesian pressurelbs. per square	e inch. Date	
CASING INSTALLED: Threaded [] Welded [] (12) WELL LOG: Dispersion of well below exclusion to better			
Of a plan from 0 ft to 31 ft Core 250			
"Diam. from		· · · · · · · · · · · · · · · · · · ·	
	Formation: Describe color, texture, grain size a and show thickness and nature of each stratum	and aquifer penetrated,	
	with at least one entry for each change of formati position of Static Water Level and indicate princ	lon. Report each change in	
PERFORATIONS: Perforated? [] Yes [X] No.	I		
Type of perforator used	MATERIAL		
Size of perforations in. by in.	Soil Brown clay		
perforations from ft. to ft.	Gravel	21 26 24	
perforations from	Sand (Medium)	26 30	
perforations from re. to	Sand and gravel	30 42	
(7) SCREENS: Well screen installed? X Yes I No	· · ·		
Manufacturer's Name Johnson Watermark			
Type <u>Stainless Steel</u> Model No. <u>304</u> Diam. <u>10<sup>11</sup></u> Slot size .020 Set from <u>26</u> ft. to <u>31</u> ft.		· ·	
Diam. 10 <sup>th</sup> Slot size $\bullet$ 020 Set from 20 ft. to 21 ft. Diam. 10 <sup>th</sup> Slot size $\bullet$ 030 Set from 31 ft. to 36 ft.			
	ind		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? 🛛 Yes 🗆 No If yes, by whom? Schoens			
Yield: 200 gal./min. with 9 ft. drawdown after 48 hrs.		·	
" " "			
n n n n n			
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.			
perature of water 54 Depth artesian flow encountered ft.	Work started 5-26 1973 Complete	d 5-30 1973	
(9) CONSTRUCTION:	Date well drilling machine moved off of well	<u>5-30 1973</u>	
Well seal-Material used Cement	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my Materials used and information reported	above are true to my	
Diameter of well bore to bottom of seal	best knowledge and belief.	1.10 13	
Diameter of well bore below seal <u>10</u> in.	[Signed] /// Drilling Machine Operator)	Date (1977), 1972	
Number of sacks of cement used in well seal <u>14</u> sacks	Drilling Machine Operator's License No.	491	
Number of sacks of bentonite used in well seal sacks			
Brand name of bentonite Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:	i – to su žeka Stratevi s tratevi	
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used?  Yes X No Plugs	Name Schoen Electric and Pump		
Did any strata contain unusable water? 🔲 Yes 🚺 No	(Person, firm or corporation) (Type or print)		
Type of water? depth of strata	Address 626 W. Queen/Albany, Gregon 97321		
Method of sealing strata off	[Signed] Lamy E. Scholm _		
Was well gravel packed?  Yes XX No Size of gravel:	(Water Well Contractor)		
Gravel placed from ft. to ft.	Contractor's License No. 513 Date	6-12, 1973	
(USE ADDITIONAL SHEETS IF NECESSARY) SP*45656-119			