

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

LINN  
8777

STATE OF OREGON  
(Please type or print)

RECEIVED  
JUL 2 1973  
STATE ENGINEER  
SALEM, OREGON

State Well No. 115/4W-35

Permit No. 6-6552

(1) OWNER:

Name Gene Bronson  
Address Box 877 Albany Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug   
Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
8" Diam. from 1.7 ft. to 71 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used dry torch  
Size of perforations 3/16 by 5 in.  
6.5 perforations from 40 ft. to 71 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " "  
" " " "  
Bailer test 45 gal./min. with 3 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 11 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 6 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County LINN Driller's well number  
1/4 Section 35 T. 11-SR. 4-W W.M.  
Bearing and distance from section or subdivision corner  
North West corner last 835'  
South 285'

(11) WATER LEVEL: Completed well.

Depth at which water was first found 23 ft.  
Static level 10 ft. below land surface. Date 6-26-73  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8  
Depth drilled 94 ft. Depth of completed well 94 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil Black	0	2	
Clay Yellow	2	17	
Clay Blue	17	22	
Sand + gravel Clay Blue	22	48	
Clay Blue Black Sand	48	52	
Sand + gravel clay			
Blue Hard	52	66	
Clay Blue	66	91	
Sand + gravel Black	91	94	
L.S. Helm			
D.L.C. 64			
notification no 1797			

Work started 6-19 19 73 Completed 6-25 19 73  
Date well drilling machine moved off of well 6-26 19 73

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Robert C White Date 6-28, 19 73  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 210

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name BOBS WELL DRILLING INC  
(Person, firm or corporation) (Type or print)

Address 465 wagon wheel Dr Lebanon  
Oreg

[Signed] Robert C White  
(Water Well Contractor)

Contractor's License No. 121 Date 6-28, 19 73