

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT

MAR 10 1969 STATE OF OREGON (Please type or print)

STATE ENGINEER SALEM, OREGON

G 4958

RECEIVED MAR 20 1969 STATE ENGINEER

11/4w-36d  
11/4w-31

(Do not write above this line)

(1) OWNER:

Name Marle R. Smith  
Address 1350 Peoria Bv Corvallis, Oregon 97330

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug   
Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

CASING INSTALLED:

10" Diam. from 2 ft. to 35 ft. Gage STD  
" Diam. from ft. to ft. Gage 1250  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used Acetylene torch  
Size of perforations 5/16 in. by 6 in.  
90 perforations from 25 ft. to 35 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 11'6" ft. below land surface Date 3-6-69  
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: 200 gal./min. with 1/2 ft. drawdown after 1/2 hrs.  
300 " 1 1/2 " 1 "  
500 " 2 1/2 " 2 1/2 "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54 Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION: Drilled with slurry

Well seal—Material used of Bentonite  
Depth of seal 18 ft.  
Diameter of well bore to bottom of seal in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(11) LOCATION OF WELL: Well No. 4

County Linn Driller's well number  
1/4 1/4 Section 31 T. 11S R. 4W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Cased to bottom Diameter of well below casing

Depth drilled 35 ft. Depth of completed well 35 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: sandy loam (0-15), cemented gravel (15-20), loose sand and gravel (20-35).

Work started 3-4-69 19 Completed 3-6-69 19

Date well drilling machine moved off of well 3-7-69 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Raymond C. Hellatly Date 3-6-1969 (Drilling Machine Operator)

Drilling Machine Operator's License No. 76

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ray Gellatly and Ron Witham (Person, firm or corporation) (Type or print)

Address Box 1 Philomath, Oregon

[Signed] Raymond C. Hellatly (Water Well Contractor)

Contractor's License No. 77 Date 3-6-69, 19