WATER WELL REPORT
STATE OF OREGON

RECEIVED
AUG 10 1984
WATER RESOURCES DEPT
SALEM, OREGON

Linn 901

State Well No. 13s/1w-26ab

State Permit No. .....

PLEASE TYPE or PRINT IN INK

(1) OWNER:

Name KENNETH DeVANEY
Address 20865 Liberty Rd.
City Sweet Home, 97386 State Or.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
[illegible] ☒ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

6" Diam. from +1 ft. to 55 ft. Gauge .250
" Diam. from ..... ft. to ..... ft. Gauge .....

LINER INSTALLED:

" Diam. from ..... ft. to ..... ft. Gauge .....

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
[illegible]id: gal./min. with ft. drawdown after hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 40 gal./min. with 20 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒
Well seal—Material used Cement & bentonite
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 12 sacks
How was cement grout placed? Tube, outside casing
.....
.....
Was pump installed? no Type ..... HP ..... Depth ..... ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs ..... Size: location ..... ft.
Did any strata contain unusable water? ☒ Yes ☐ No
Type of Water? rusty depth of strata 1' at 19'
Method of sealing strata off cemented
Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:

County LINN Driller's well number
NW ¼ NE ¼ Section 26 T. 13S R1W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: Same

(11) WATER LEVEL: Completed well.

Depth at which water was first found 19 ft.
Static level 15 ft. below land surface. Date 7/24
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 69 ft. Depth of completed well 69 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil & clay, brown	0	10	
Clay, blue brown	10	19	15
Sandy clay & gravel, rust	19	20	
Claystone, blue	20	30	
Conglomerate, blue	30	64	
" " soft	64	69	24

Work started 7/24 19 84 Completed 7/30 19 84
Date well drilling machine moved off of well 7/31 19 84

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] ..... Date ....., 19.....

Bonded Water Well Constructor Certification:

Bond SLR6386707 (number) Issued by: Firemans Fund (Surety Company Name)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name H&H DRILLING (Person, firm or corporation) (Type or print)
Address 39081 Golden Valley Dr. Lebanon, Or.
[Signed] [illegible] Water Well Constructor
Date 8/5, 1984

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690