NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
NOV 28 1966
STATE ENGINEER
SALEM OREGON

LINN
9582

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 12/1W-29E

G-3800 State Permit No.

(1) OWNER:
Name Junior Oakley
Address Star Route #2, Box 16
Lebanon Oregon 97355

(2) LOCATION OF WELL:
County Linn Driller's well number
¼ ¼ Section 30 T. 12S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 60 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Torch
Size of perforations 1/4 in. by 6 in.
62 perforations from 59 ft. to 60 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 28 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 8 ft. below land surface Date 11-17-66
Artesian pressure ? lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 60 gal./min. with 8 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing 8
Depth drilled 60 ft. Depth of completed well 60 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Rocky Soil	0	2
Clay + Boulders	2	30
hard packed sand	30	34
Boulders + sand	34	50
sand + gravel	50	60

Work started 11-9 1966 Completed 11-17 1966
Date well drilling machine moved off of well 19

(13) PUMP:
Manufacturer's Name Fairbanks Morse
Type: Turbine H.P. 3 hp

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Willamette Irrigation & Gin Co
(Person, firm or corporation) (Type or print)
Address Star Route #2, Box 5 Lebanon
Drilling Machine Operator's License No. 31
[Signed] Carl H Saunders
(Water Well Contractor)
Contractor's License No. 149 Date 11-23, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)