

WATER WELL REPORT
STATE OF OREGON

RECEIVED

Malheur
1071

State Well No. 18S/45E-23
State Permit No. da

APR 27 1988 PLEASE TYPE or PRINT IN INK

(1) OWNER: WATER RESOURCES DEPT.
SALEM, OREGON
Name Kirt Adams
Address P.O. Box 221
City Ontario State Oregon
97914

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: **(4) PROPOSED USE (check):**
Rotary Air Driven Domestic Industrial Municipal
Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(5) CASING INSTALLED: Steel Plastic
Threaded Welded
8" Diam. from +1 ft. to 30 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used Torch
Size of perforations 1/4 in. by 1 in.
60 perforations from 20 ft. to 30 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test 50 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 51 Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? Pressure Grouted
Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Malheur Driller's well number
N.E. 1/4 S.E. 1/4 Section 23 T. 18 R. 45 W.M.
Tax Lot # 1801 Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.
Depth at which water was first found 17 ft.
Static level 12 ft. below land surface. Date 3/31/88
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8
Depth drilled 50 ft. Depth of completed well 50 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	15	
Gravel	15	29	
Blue Sandstone	29	50	

Work started 3/30 1988 Completed 3/31/88 19
Date well drilling machine moved off of well 3/31/88 19

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:
Bond U45-8259 Issued by: United Pacific Ins. Co
(number) Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name PAT PAGE WELL DRILLING (Type or print)
Address 590-15th St. N. Vale, Oregon
[Signed] Winfield Page 97918
Water Well Constructor
Date 4/31/88, 19