

**WATER WELL REPORT**  
STATE OF OREGON

**RECEIVED**

*Malheur*  
*1072*

State Well No. 185/45E-23  
State Permit No. da

APR 27 1988 PLEASE TYPE or PRINT IN INK

**(1) OWNER:**

Name Kirt Adams  
Address P.O. Box 221 Ontario, Oregon 97918  
City Ontario State Oregon

WATER RESOURCES DEPT.  
SALEM, OREGON

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven   
Mud  Dug   
 Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other   
Thermal: Withdrawal  Reinjection

**(5) CASING INSTALLED:**

Steel  Plastic   
Threaded  Welded

12" Diam. from +1 ft. to 19 ft. Gauge .250  
" Diam. from ..... ft. to ..... ft. Gauge .....

**LINER INSTALLED:**

" Diam. from ..... ft. to ..... ft. Gauge .....

**(6) PERFORATIONS:**

Perforated?  Yes  No

Type of perforator used Torch  
Size of perforations 1/4 in. by 1 in.  
60 perforations from 18 ft. to 28 ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name ..... Model No. ....  
Type .....  
Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

a pump test made?  Yes  No If yes, by whom? Riverside Electric.  
Yield: 75 gal./min. with 93 ft. drawdown after 1 hrs.

Air test gal./min. with drill stem at ..... ft. hrs.

Bailer test gal./min. with ..... ft. drawdown after ..... hrs.

Artesian flow g.p.m.

Temperature of water 52 Depth artesian flow encountered ..... ft.

**(9) CONSTRUCTION:**

Special standards: Yes  No

Well seal—Material used Cement

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 16 in.

Diameter of well bore below seal 12 in.

Number of sacks of cement used in well seal 8 sacks

How was cement grout placed? Pressure Grouted

Was pump installed? ..... Type ..... HP ..... Depth ..... ft.

Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.

Did any strata contain unusable water?  Yes  No

Type of Water? ..... depth of strata

Method of sealing strata off

Was well gravel packed?  Yes  No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL:**

County Malheur Driller's well number  
N.E. 1/4 S.E. 1/4 Section 23 T. 18 R. 45 W.M.  
Tax Lot # 1801 Lot Blk Subdivision

Address at well location:

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 23 ft.  
Static level 12 ft. below land surface. Date 3/24/88  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 12

Depth drilled 115 ft. Depth of completed well 115 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	15	
Gravel	15	28	
Blue Sandy Clay	28	35	
Blue Clay	35	49	
Blue Sandstone	49	70	
Blue Sand stone & pea grav.	70	115	
Blue Clay	115		

Work started 3/15 19 88 Completed 3/24/ 19 88  
Date well drilling machine moved off of well 3/24 19 88

**(unbonded) Water Well Constructor Certification (if applicable):**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] ..... Date ....., 19.....

**Bonded Water Well Constructor Certification:**

Bond U45-8259 Issued by: United Pacific Ins Co.  
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name PAT PAGE WELL DRILLING  
(Person, firm or corporation) (Type or print)

Address 590-15th. St. N. Vale, Oregon 97918

[Signed] Winifred Page  
Water Well Constructor Date 3/24, 19 88