

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON APR 28 1975

State Well No. 185/47E-2cc

(Please type or print)

STATE ENGINEER
SALEM, OREGON

State Permit No.

NC
Maltb
1278

(1) OWNER:

Name MRE Ida Foods
Address ONTARIO, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

12" Diam. from 27.2 ft. to 29 ft. Gage 375
10" Diam. from 27.6 ft. to 30 ft. Gage 250
" Diam. from 40 ft. to 48 ft. Gage 250

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name JOHN SONS
Type STAINLESS Model No.
Diam. 10 Slot size 40 Set from 30 ft. to 40 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No. If yes, by whom?
Yield: 220 gal./min. with 17 ft. drawdown after 2 hrs.
~~220~~ " " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 18 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 1 1/2 yard sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County MALHEUR Driller's well number
SW 1/4 SW 1/4 Section 2 T. 18S R. 47E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 29 ft.
Static level 10 ft. below land surface. Date 4/11/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 48 ft. Depth of completed well 48 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	8	
GRAVEL CORSE (CLAY)	8	28	
GRAVEL SAND (MEDIUM)	28	40	
BLUE CLAY	40	48	

Work started 4/8/ 1975 Completed 4/28/ 1975

Date well drilling machine moved off of well 4/29/ 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Kenneth H. Witt Date 4/29/1975
(Drilling Machine Operator)

Drilling Machine Operator's License No. 610

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Kenneth H. Witt (Type or print)
(Person, firm or corporation)

Address Caldwell, Idaho

[Signed] Kenneth H. Witt
(Water Well Contractor)

Contractor's License No. 498 Date 4/29/ 1975