

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

malh 1280

WATER WELL REPORT JUN 5 1974

STATE OF OREGON STATE ENGINEER SALEM, OREGON

State Well No. 185/47E-2 CC State Permit No.

(1) OWNER:

Name ORE. IDA FOODS INC Address ONTARIO, OREGON

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [x] Irrigation [] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded []

16" Diam. from 0 ft. to 20 ft. Gage 375... 12" Diam. from 22 ft. to 21 ft. Gage 375... 10" Diam. from 31 ft. to 40 ft. Gage 250... 8" " " 18'6" TO 21 FT PACKER INCLUDED

PERFORATIONS:

Perforated? [] Yes [x] No

Type of perforator used

Table with columns: Size of perforations, in. by, in. Rows for perforations from 0 to 40 ft.

(7) SCREENS:

Well screen installed? [x] Yes [] No

Manufacturer's Name JOHNSON Type STAINLESS Model No. PS Diam. 10 Slot size 50 Set from 21 ft. to 31 ft.

(8) WATER LEVEL: Completed well.

Static level 10'6" ft. below land surface Date Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom? 250 gal./min. with 9 ft. drawdown after 8 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [x] Yes [] No

(10) CONSTRUCTION:

Well seal—Material used CEMENT GRAUTE Depth of seal 20 FT Diameter of well bore to bottom of seal 18 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MALHEUR Driller's well number 3 SW 1/4 SW 1/4 Section 2 T. 18 S R. 47 E W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows: Top Soil, Silty Clay, Sand Gravel, Gravel Medium, Sandy Clay, Sand Gravel Medium, Blue Clay.

Work started 3/26/ 1974 Completed 4/6 1974 Date well drilling machine moved off of well 4/6 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Kenneth Witt Date 3/22, 1974 (Drilling Machine Operator)

Drilling Machine Operator's License No. 610

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kenneth Witt and Sons (Person, firm or corporation) (Type or print)

Address Caldwell, Idaho

[Signed] Kenneth Witt (Water Well Contractor)

Contractor's License No. 498 Date 4/6, 1974