

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT JUN 5 1974

STATE OF OREGON STATE ENGINEER SALEM, OREGON

State Well No. 185/47E-2cc
State Permit No. _____

*Malheur
1282*

(1) OWNER:

Name ORE. IDA FOODS INC.
Address ONTAIRE, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

16" Diam. from 0 ft. to 20 ft. Gage 375 WALL
12" Diam. from 0+2 ft. to 22 ft. Gage 375 WALL
10" Diam. from 32 ft. to 40 ft. Gage 250 WALL

(6) PERFORATIONS:

0" " 19 FT " 22 FT PACKER PERFORATED? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name JOHNSON
Type STAINLESS Model No. _____
Diam. 10 Slot size 50 Set from 22 ft. to 32 ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 10 FT 8" ft. below land surface Date 5/22/74
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
1: 305 gal./min. with 11 ft. drawdown after 8 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT GRAUTE
Depth of seal 20 FT ft.
Diameter of well bore to bottom of seal 18 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County MALHEUR Driller's well number W5A
SW 1/4 SW 1/4 Section 2 T. 18 S. R. 47 E. W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	8	
Silty Clay Gravel	8	12	
GRAVEL, SAND (FINE)	12	21	11 FT
GRAVEL MEDIUM SAND	21	32	11 FT
Blue Clay	32	40	

Work started 5/13 1974 Completed 5/22 1974
Date well drilling machine moved off of well 5/27 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Kenneth Witt Date 5/27/1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 610

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kenneth Witt and Sons
(Person, firm or corporation) (Type or print)

Address Caldwell, Idaho

[Signed] Kenneth Witt
(Water Well Contractor)

Contractor's License No. 498 Date 5/27/1974