ORIGINAL File Original and Duplicate with the STATE ENGINEER, SALEM, OREGON WATER WEI	OREGON State Permit No.
(1) OWNER: Name Oregon Industries Company Address 789 N. E. 1st St. Ontario, Oregon	Tests: Drawdown is amount water level is lowered below static level harrod & Was a pump test made? May yes on the lowered below static level harrod & Wield: 200 gal./min. with 30 ft. drawdown after 48 hrs.
(2) LOCATION OF WELL: County Malheur Owner's number, if any NW 1/4 Section 3 T. 18 R. 47 F. W.M.	Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 55 Was a chemical analysis made? Yes No
NW 14 14 Section 3 T. 18 R. 47 E.W.M. Bearing and distance from section or subdivision corner N 68 03 W 208.58 ft. from SE Cor. NW 2 S 3 T 18 S R 47 E.W.M.	(12) WELL LOG: Depth drilled 30 ft. Depth of completed well 30 ft.
	Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation. MATERIAL FROM TO
New Well \(\text{X} \) Deepening \(\square\) Reconditioning \(\square\) Abandon \(\square\) If abandonment, describe material and procedure in Item 11.	Drilled through silt into gravel stopped at blue shale
(4) PROPOSED USE (check): Comestic ☐ Industrial ☐ Municipal ☐ Cable ☐ Jetted ☐ Dug ☐ Bored ☐	
(6) CASING INSTALLED: Threaded □ Welded ▼ " Diam. from 0 ft. to 30 ft. Gage	
(7) PERFORATIONS: Type of perforator used Acytelene SIZE of perforations 3/8 in. by 6 in. 500 perforations from 10 ft. to 30 ft. perforations from ft. to ff. perforations from ft. to ff. perforations from ft. to ff.	
(8) SCREENS: Well screen installed Types I No Type Perforated Suction Model No.	
Diam. 6 Slot size 3/8 Set from ft. to 30 ft. Diam. Slot size Set from ft. to ft. to ft.	Work started May 19 5.7 Completed May 19 5.7 (13) PUMP:
(9) CONSTRUCTION: Was well gravel packed? ☐ Yes XNo Size of gravel: Gravel placed fromft. toft. Was a surface seal provided? ☐ Yes ☐ No To what depth?ft. Material used in seal—	Manufacturer's Name Pomona Unidrive Type: Turbine H.P. 7.5 Well Driller's Statement: This well was drilled under my jurisdiction and this report is
Did any strata contain unusable water?	true to the best of my knowledge and belief. NAME (Person, fign, cr corporation) (Type or print)
Static level 18 ft. below land surface Date May, 19 Artesian pressure none lbs. per square inch Date Log Accepted by: OPEGON INDUSTRIES COMPANY	Driller's well number 226
[Signed] My Juggpate 2-26 , 19.58	(Well Driller)

18/47-3F (1)