

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON SEP 30 1974 State Well No. 185/47E-11
(Please type or print) STATE ENGINEER State Permit No. 66892
SALEM, OREGON G-6892

(1) OWNER:
Name CITY ONTARIO
Address ONTARIO, OREGON

(10) LOCATION OF WELL:
County Malheur Driller's well number 9
¼ Section 11 T. 185 R. 47E W.M.
Bearing and distance from section or subdivision corner
LOT 1

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 32 ft.
Static level 17 ft. below land surface. Date 9/20/74
Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL: Rotary Cable Dug
(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other

(12) WELL LOG: Diameter of well below casing NONE
Depth drilled ft. Depth of completed well 49 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

(6) CASING INSTALLED: Threaded Welded
12" Diam. from 0+18" ft. to 35 ft. Gage 375
10" Diam. from 34 ft. to 35.6' ft. Gage 250
10" Diam. from 41 ft. to 49 ft. Gage 250

MATERIAL	From	To	SWL
TOP SOIL	0	6	
SANDY CLAY	6	16	
LARG GRAVEL, CLAY	16	24	
CLAY GRAVEL SAND	24	30	
(MEDIUM GRAVEL SAND)	30	42	17
SOME CLAY			
BLUE CLAY	42	50	

(7) PERFORATIONS: Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name JOHNSON
Type STAINLESS Model No. 304
Diam. 12" Slot size 60 Set from 36 ft. to 41 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? CONTR
Yield: 210 gal./min. with 14 ft. drawdown after 8 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

Work started 9/9 19 74 Completed 9/26/ 19 74
Date well drilling machine moved off of well 9/26/ 19 74

(9) CONSTRUCTION:
Well seal—Material used CEMENT GROUT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 1 yrd sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Kenneth Witt Date _____, 19____
(Drilling Machine Operator)
Drilling Machine Operator's License No. 610

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name KEVINETH WITT (Type or print)
(Person, firm or corporation)
Address CALDWELL, IDAHO
[Signed] Kenneth Witt
(Water Well Contractor)
Contractor's License No. 498 Date 9/26/, 19 74