

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

NO  
WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON  
(Please type or print)

SEP 13 1974 State Well No. 185/47E-11  
STATE ENGINEER State Permit No. \_\_\_\_\_  
SALEM, OREGON G6892

(1) OWNER:

Name CITY ONTARIO  
Address ONTARIO, OREGON

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
12" Diam. from 0118" ft. to 32 ft. Gage 375 WALL  
10" Diam. from 31 ft. to 32 ft. Gage 250  
" Diam. from 37 ft. to 48 ft. Gage 250

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name JOHNSON  
Type STAINLESS Model No. 304  
Diam. 1.25 Slot size 60 Set from 32 ft. to 37 ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? CONTR  
Yield: 275 gal./min. with 12 ft. drawdown after 8 hrs.  
" " " " " "  
" " " " " "  
Galler test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GRAVEL  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 16 in.  
Diameter of well bore below seal 12 in.  
Number of sacks of cement used in well seal 1 YARD sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons  
of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County MALHEUR Driller's well number 8  
1/4 1/4 Section 11 T. 185 R. 47E W.M.  
Bearing and distance from section or subdivision corner  
LOT 1

(11) WATER LEVEL: Completed well.

Depth at which water was first found 23 ft.  
Static level 19 ft. below land surface. Date 8/29/74  
Artesian pressure lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing NONE  
Depth drilled 48 ft. Depth of completed well 48 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	5	
LARGE GRAVEL	5	14	
MEDIUM GRAVEL	14	20	
MEDIUM SAND GRAVEL	20	25	19
MEDIUM GRAVEL, CLAY	25	32	
MEDIUM SAND, GRAVEL	32	38	19
BLUE CLAY, SANDY	38	48	

Work started 8/27/1974 Completed 9/9/1974  
Date well drilling machine moved off of well 9/9/1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Kenneth Witt Date 9/10/74  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 610

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Kenneth Witt  
(Person, firm or corporation) (Type or print)  
Address City Well, Idaho  
[Signed] Kenneth Witt  
(Water Well Contractor)  
Contractor's License No. 498 Date 9/10/1974