

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are filed with the

WATER WELL REPORT

STATE OF OREGON

State Well No. 18/47-11 ba

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or print) (Do not write above this line)

State Permit No. G-4761

(1) OWNER:

Name City ONTARIO Address ONTARIO OREGON

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Cable [X] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [X] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

16" Diam. from 0 ft. to 21 ft. Gage 375 WALL 8" Diam. from 0 ft. to 21 ft. Gage 250 WALL 8" Diam. from 38 ft. to 50 ft. Gage 250 WALL

PERFORATIONS:

Perforated? [ ] Yes [ ] No. Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [X] Yes [ ] No Manufacturer's Name JOHN SON Type STAINLESS STEEL Model No. Diam. 8 P.S. Slot size 50 Set from 21 ft. to 38 ft.

(8) WATER LEVEL: Completed well.

Static level 4' 2" ft. below land surface Date Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [X] Yes [ ] No If yes, by whom? PARNAS WATER LIFTER Yield: 250 gal./min. with 34 ft. drawdown after 24 hrs.

(10) CONSTRUCTION:

Well seal—Material used CEMENT GROUT Depth of seal 20 Diameter of well bore to bottom of seal 22 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [X] Yes [ ] No Size of gravel: 3/16 MIN MAX Gravel placed from 0 ft. to 50 ft.

(11) LOCATION OF WELL:

County MALHEUR Driller's well number 5 1/4 Section 11 T.18 S.R. 47 E W.M. Bearing and distance from section or subdivision corner LOT 1

(12) WELL LOG:

Diameter of well below casing 16" Depth drilled 50 ft. Depth of completed well 50 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: TOP SOIL (Blue), SILT GRAVEL SAND (FINE), GRAVEL (MEDIUM), GRAVEL SAND DARK, CLAY, BLUE SANDY.

Work started 2/11/1969 Completed 3/11/1969 Date well drilling machine moved off of well 3/11/1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Kenneth Witt (Drilling Machine Operator) Date 3/26, 1969

Drilling Machine Operator's License No. 610

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME WITTE AND SONS (Person, firm or corporation) (Type or print) Address R.#4, Caldwell, Idaho [Signed] Kenneth Witt (Water Well Contractor) Contractor's License No. 498 Date 3/26/1969