NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR 11 1968 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

Malh 1694

State Well No. 18/47-17 M

State Permit No. G-4438

(1) OWNER:
Name Archid A Bros
Address Ontario. Ore.

(2) LOCATION OF WELL:
County Malhur Driller's well number
¼ ¼ Section 17 T. 18 R. 47 W.M.
Bearing and distance from section or subdivision corner
N½ N½ SW¼ N½ NW¼ SE¼
South line - 875' from Hiway

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
14" Diam. from 0 ft. to 60 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Factory
Size of perforations 1/4 in. by 4 in.
572 perforations from 30 ft. to 60 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 18 ft. Was a packer used? No
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 1"
Gravel placed from 18 ft. to 60 ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 7 ft. below land surface Date 3-27
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Hysell Pump
Yield: 550 gal./min. with 55 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:
Diameter of well below casing 14
Depth drilled 65 ft. Depth of completed well 65 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Clay	0	20
Med gravel	20	25
Sand	25	30
Pea gravel	30	42
Med to coarse gravel	42	60
Blue Shale	60	65

Work started 3-21 1968 Completed 3-27 1968
Date well drilling machine moved off of well 3-29 1968

(13) PUMP:
Manufacturer's Name Jacuzzi
Type: Turbin H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Hysell Pump & Drilling
(Person, firm or corporation) (Type or print)
Address Vale, Ore
Drilling Machine Operator's License No. 65
[Signed] Glen Hysell
(Water Well Contractor)
Contractor's License No. 396 Date 4-10, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)