STATE OF OREGON				
WATER WE				

(as required by OR

RE	C	E	V	E	D	

144E-6ad

MAR 1 9 1986 SE TYPE	or PRINT IN INK	(for official use only)			
(1) OWNER: WATER RESOURCES DEPT	(10) LOCATION OF WELL by lega	d description:			
NameEagle-Picher SALEM, OREGON	County Malheur S. E. N. E.	of Section 6 of			
Address P.O Box 640	Township, Range, Range	+ WM.			
City Vale State Oregon	2000				
(2) TYPE OF WORK (check): 97918	Tax Lot Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address)				
New Well Deepening Reconditioning Abandon	P.O. Box 640-Vale, Oregor	1 97918			
If abandonment, describe material and procedure in Item 12.					
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLET	TED WELL:			
Rotary Air Driven Domestic X Industrial Municipal	Depth at which water was first found	100 ft.			
Rotary Mud Dug Di Irrigation Withdrawal Reinjection D	Static level +1 ft. below land surface. Date 3-4-86				
Other: Bored Piezometric Grounding Test	Artesian pressure lbs. per	square inch. Date			
	(12) WELL LOG: Diameter of well below	v casing 1.2			
(5) CASING INSTALLED: Steel 🕅 Plastic 🗆 Threaded 🗎 Welded 🕅		f completed well 120 ft			
12 "Diam. from +3 ft. to 33 ft. Gauge 250	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of				
" Diam. from ft. to ft. Gauge	formation. Report each change in position of Static Wat	east one entry for each change of ter Level and indicate principal			
	water-bearing strata.				
LINER INSTALLED: Steel Threaded Welded	MATERIAL	From To SWL			
	Top Soil	0 10			
(6) PERFORATIONS: Perforated?  Yes X No	Brown Clay	10 15			
Size of perforations in. by in.	Brn. Clay & Pea Gravel	15 20			
	Brn. Clay & Gravel	20 26			
perforations from	Gravel & Boulders	26 28			
perforations from	Sand Stone	28 60			
	Volcanic Ash	60 98			
(7) SCREENS: Well screen installed?  Yes X No	Blue Sand Stone	98 120			
Manufacturer's Name					
Diam					
Diam. Slot Size					
(8) WELL TESTS: Drawdown is amount water level is lowered below static level					
Was a pump test made? X Yes . No If yes, by whom?					
1: 255 gal./min. with ft. drawdown after hrs.					
		<u></u>			
Air test gal./min. with drill stem at ft. hrs.					
Bailer test 50 gal/min. with 16 ft. drawdown after 1 hrs. Artesian flow c.p.m.					
	Date work started 2-22-86/complete	d <b>3-4-86</b>			
(9) CONSTRUCTION: Special standards: Yes D No 🕅	Date well drilling machine moved off of well	3-4-86 19			
Well seal-Material used Cement	(unbonded) Water Well Constructor Certifica				
Well sealed from land surface to	This well was constructed under my direct supe				
Diameter of well bore to bottom of seal	information reported above are true to my best kno	wledge and belief.			
Amount of sealing material	[Signed]	Data 10			
How was cement grout placed? Pressure Grouted					
	(bonded) Water Well Constructor Certificatio Bond#U45-8259 Issued by United	n: Dogifia Tro Tro			
	(Sure	Pacific Ins. Inc ty Company Name)			
Was pump installed? Type HP Depth ft.	On behalf of Winfield L. Page	her Well Ormeter (			
Was a drive shoe used? KYes D No Plugs Size: location ft.	(type or print name of Wat	,			
Did any strata contain unusable water? Ves X No	This well was drilled under my jurisdiction and this report is true to the				
Type of Water? depth of strata	best of my knowledge and belief:	52			
Method of sealing strata off	(Signed) (Weer Well Construction	rage-			
Was well gravel packed?  Yes X No Size of gravel:	(Dated) 3-17-86	*' <i>(</i>			
Gravel placed from ft. to ft.					
NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the	WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.	SP*46866-690			