(182) Malh

Tracy #1

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON, within 30 days from the date of well completion.

RECEIVED OCT 11 1965 STATE ENGINEER SALEM OREGON

RECEIVED NOV 10 1965 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 19/44-11N

G-4156

G-3346

State Permit No.

(1) OWNER:
Name Harry Tracy
Address 759 Lee St.
Lake Oswego, Oregon

(2) LOCATION OF WELL:
County Malhuer Driller's well number
¼ ¼ Section T. 19 S R. 44-E W.M.
Bearing and distance from section or subdivision corner
South ½ section 11

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 30 ft. Gage .025
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used torch
Size of perforations ¼ in. by 8 in.
96 perforations from 18 ft. to 30 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal cement
Depth of seal 18 ft. Was a packer used? No
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 10 ft. below land surface Date 9/17/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Hysell
Yield: 650 gal./min. with — ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:
Diameter of well below casing 12"
Depth drilled 43 ft. Depth of completed well 43 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
top soil	0	18
sand and gravel	18	30
yellow clay	30	32
sand and gravel	32	43

Work started 9/15 19 . Completed 9/17 1965
Date well drilling machine moved off of well 9/20 1965

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Hysell Pump + Drilling (Person, firm or corporation) (Type or print)
Address Vale Ore
Drilling Machine Operator's License No. 655
[Signed] [illegible] Hysell (Water Well Contractor)
Contractor's License No. 396 Date , 19

(USE ADDITIONAL SHEETS IF NECESSARY)