
## WATER WELL REPORT STATE OF OREGON



## RECEIVED JUL 141983

LEASE TYPEWATER REFOURCES DEPT. Permit No. SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name ALVIN ANDERSON	County MALITUER Driller's well number #3
Address P.O. BOX 3282	SW 4 NW4 Section 15T. 195 R. 46 E W.M.
City DVSSA State ORE 97913	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well    Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 295 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 270 ft. below land surface. Date 6/17/83
Rotary Air Driven Domestic Industrial Municipal Rotary Mud Dog Irrigation Test Well Dother D	Artesian pressure lbs. per square inch. Date
Bored	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel  Plastic	Depth drilled 490 ft. Depth of completed well 490 ft.
12 "Diam from ft. to 193 ft. Gauge Welded 250"  Threaded Welded 250  Welded 250  Welded 250  Gauge 550  Welded 500  Gauge 550  Welded 500  Gauge 550  Gauge 550  Welded 500  Gauge 550  Welded 500  St. Gauge 550  St. Gauge 550	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report ēach change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	501k 0 3
	Caliene 35
(6) PERFORATIONS: Perforated? ☐ Yes X No Type of perforator used	Brown clay med grave 5 8
Size of perforations in. by in.	Brown clay 8 40
perforations from	Brown sand med grave 40 193
perforations from	Brown clay 193 294 278
perforations from ft. to ft.	Brown Sandstone med
	grave 1 294 305 270
(7) SCREENS: Well screen installed? ☐ Yes X No	Brown clay sandy 305365270
Manufacturer's Name  Type Model No	blue alay sandy 365 455 270
Diam. Slot Size Set from ft. to ft.	Blue clay 455 490 200
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made?	
Held: 400 gal./min. with 210ft. drawdown after 4 hrs.	
<i>II</i>	
$\underline{\text{Air test}} \hspace{1cm} \text{gal./min. with drill stem at} \hspace{1cm} \text{ft.} \hspace{1cm} \text{hrs.}$	
esian flow g.p.m.	
Temperature of water 74 Depth artesian flow encountered ft.	Work started 6/15 19 83 Completed 6/22 1983
(9) CONSTRUCTION: Special standards: Yes □ No 🗶	Date well drilling machine moved off of well 6/22 1983
Well seal—Material used Portland Cement	(unbonded) Water Well Constructor Certification (if applicable):
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealdin.	[Signed]
Number of sacks of cement used in well seal	Bonded Water Well Constructor Certification:
How was cement grout placed? Graut pump	Bond A-7933149 Issued by: MILLER Group of Texas
	This well was drilled under my jurisdiction and this report is true to
Was pump installed?	the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes No Plugs	Name Bowns Drilling (Type or print)
Did any strata contain unusable water?   Yes  No	Address P.O. BOX 41 Jamiesow OR 97909
Type of Water? depth of strata	[Signed] Gerbert H. Bownan
Method of sealing strata off	Water Well Constructor
Was well gravel packed? X Yes □ No Size of gravel:	Date
Gravel placed from 20 ft to 490 ft	1