

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

MALH 1899 RECEIVED

RECEIVED

WATER WELL REPORT
STATE OF OREGON

MAY 21 1979

State Well No. 195/46E-2/cb

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

APR 4 1979 (Please type or print)

WATER RESOURCES DEPT.
SALEM, OREGON

State Permit No. Malh 1899

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name J. A. ALBERTSON
Address 800 Houston Rd
Boise, Idaho

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from 0+2 ft. to 53.6 ft. Gage 375 Wall
10" Diam. from 49.2 to 58.0 ft. Gage 250
10" Diam. from 59.0 ft. to 65.0 ft. Gage 250
" " 65.5 " 69.0 " 250
" " 70.0 " 85.0 " 250
" " 86.0 " 87.0 " 250
Type of perforator used
Size of perforations in. by in.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name J. H. N. S. O. N.
Type STAINLESS Model No. 308
Diam. 1.0 Slot size 35 Set from 58.0 ft. to 59.0 ft.
" Diam. 1.0 Slot size 33 Set from 65.0 ft. to 65.5 ft.
" Diam. 1.0 Slot size 35 " 69.0 " 70.0 ft.
" Diam. 1.0 Slot size 35 " 85.0 " 86.0 ft.

(8) WELL TESTS:

Drawdown & amount water lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 145 gal./min. with 135 ft. drawdown after 24 hrs.
" 145 " " " " "
" " " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 2.0 in.
Diameter of well bore below seal 1.6 in.
Number of sacks of cement used in well seal 5.4 sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Qu. Kegel
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: DE MONTE #8
Gravel placed from 5.00 ft. to 10.00 ft.

(10) LOCATION OF WELL:

County MALHEUR Driller's well number
NW 1/4 SW 1/4 Section 21 T. 19S R. 46 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 390 ft.
Static level 32.5 ft. below land surface. Date 3/20/79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing No Hole
Depth drilled 1000 ft. Depth of completed well 870 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	5	
GRAVEL	5	7	
SANDY CLAY BROWN SHALE (Grey)	7	365	
SHALE SANDY BLUE SHALE	365	410	
SHALE GRAY	410	430	390
SANDY SHALE	430	510	
SANDY SHALE	510	575	385
SANDY 15% CLAY	575	580	
SHALE GREY STICKY	580	590	385
SOFT SHALE SANDY	590	650	
SHALE (Grey) STICKY	650	655	380
(SOFT) SANDY CLAY	655	690	
STICKY SHALE BLUE	690	703	342
SHALE GREY	703	809	
STICKY CLAY	809	820	
GREY SAND, MEDIUM GRAVEL	820	848	
STICKY CLAY BLUE	848	860	340
FILLED HOLE BACK TO 870 FT WITH PACK	860	1000	NO WATER
Work started	9/27/1978	Completed	3/11 1979
Date well drilling machine moved off of well	3/27		1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ch. Duke Date 3-24, 1979
(Drilling Machine Operator)
Drilling Machine Operator's License No. 611

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WITT DRILLING
(Person, firm or corporation) (Type or print)
Address CALDWELL, IDAHO
[Signed] Kenneth Witt
(Water Well Contractor)
Contractor's License No. 498 Date 3/11/, 1979

Well # 9



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.wrd.state.or.us

Application for
Well ID Number

RECEIVED

FEB 08 2016

Do not complete if the well already has a Well Identification Number.

WATER RESOURCES DEPT
SALEM, OREGON

I. OWNER INFORMATION

Current Owner Name (please print): Hans Nederend
Mailing Address: Hogg Road
City, State, Zip: Homedale, ID 83628
Mail Well ID Tag to: [] SAME AS ABOVE [x] In Care Of (C/O)
Name & Address: Riverside Inc. 111 S. Roswell Blvd
City, State, Zip: Parma, ID 83660

II. WELL LOCATION INFORMATION (Please fill out as completely as possible)

Township: 19 South (North / South) Range: 46 East (East / West) Section: 21
Tax Lot: 4700 County Malheur NW 1/4 SW 1/4
GPS Coordinates: 43.916389, -117.1025
Street Address of Well, City: 3455 Victorio Rd, Nyssa, OR 97913
If the property had a different street address in the past:

III. GENERAL WELL INFORMATION (Please fill out as completely as possible)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): Irrigation/Stock
Date Well Constructed (or property built): Total Well Depth: 860 Casing Diameter: 16
Owner at time the well was constructed (if known):
Other Information:

SUBMITTED BY (please print): Cody Daugherty
PHONE: 208-722-6731 EMAIL &/or FAX: cody@rsicorp.net

Send application to: Oregon Water Resources Department 725 Summer St NE, Suite A, Salem, Oregon 97301; or fax to (503) 986-0902. Applications are processed in the order they are received, and Well ID Numbers are mailed within 4-5 business days.

For Official Use Only by the Oregon Water Resources Department:

Received Date:

2-8-16

Well Log Number:

MALH 1899

Well Identification #:

L-121716