NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT CELV ESTATE OF OREGON SALEM, OREGON 97310 within 30 days from the date of well completion.

JAN24197 on twrite above this line JAN241979 not write above this line)

nadi	State	Well 1	To. 🤦	15/	46E	75c
222	State	Permi	t No.			

(1) OWNER: WATER RESOURCES DEPT.	(10) LOCATION OF WELL:				
Name Adrian Gity Well SALEM. OREGON	CountMalheur Driller's well number				
Address Adrian, Oregon	S.W 1/4 S.W 1/4 Section 15 T.21 R.46 W.M.				
	Bearing and distance from section or subdivision corner				
(2) TYPE OF WORK (check):	<u> </u>				
New Well F Despening Reconditioning Abandon Abandon If abandonment, describe material and procedure in Item 12.					
	(11) WATER LEVEL: Completed well.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 362 ft.				
Rotary Driven Domestic Industrial Municipal Domestic	Static level 1 ft. below land surface. Date 11-14				
Dug	Artesian pressure lbs. per square inch. Date				
CASING INSTALLED: _Threaded Welded	(19) WHIT LOC				
8	(12) WELL LOG: Diameter of well below casing				
" Diam, fromft, toft. Gage	Depth drilled 101 ft. Depth of completed well 101 ft.				
"Diam. from ft. Gage ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,				
	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.				
PERFORATIONS: Perforated? Yes No.					
Type of periorator asea	MATERIAL From To SWL				
Size of perforations in. in. by	Brown Sand; Clay 0 28 28 38				
perforations fromft. toft.	Brown Clay				
perforations from ft. to ft.	Blue Clay 38 362				
perforations fromft. toft.	Black Coarse Sand 362 369				
(7) SCREENS: Well screen installed? Yes X No	Silt Stone 369 401				
Manufacturer's Name	- 				
Type Model No.					
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.					
Diam. Stot ize Set from It. to 11.					
(8) WELL TESTS: Drawdown is amount water level is lowered below static level					
Was a pump test made? A Yes No If yes, by whom Page Bros.					
Yield: 50 gal/min. with 266st. drawdown after), hrs.					
n' n'	- E				
n 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					
Bailer test it gal./min. with ft. drawdown after hrs.					
Artesian flow g.p.m.					
perature of water 72 Depth artesian flow encountered ft.	Work started 77-71-78 19 Completed 11-30-78 19				
Depart arestair now encountered					
(9) CONSTRUCTION:	Date well drilling machine moved off of well 11-30-78 19				
Well seal—Material used Comont	Drilling Machine Operator's Certification:				
Well sealed from latid surface to .27	This well was constructed under my direct supervision. Materials used and information reported above are true to my				
Diameter of well bore to bottom of seal 12in.	best knowledge and belief				
Diameter of well bore below seal	[Signed] Date 11_30, 1978.				
How was cement grout placed? Pressure grouted	Drilling Machine Operator's License No				
A STATE OF THE STA	Water Well Contractor's Certification:				
and the second of the second o	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Was a drive shoe used? ➤ Yes □ No Plugs Size: location ft.	Name PAGE BROS DRILLING (Person, firm or corporation) (Type or print)				
Did any strata contain unusable water? Yes 1 No					
Type of water? depth of strata	Address T. 2- Box 371- WATE OREGON 97918				
Method of sealing trata off	[Signed] MANACON WALL COMPANY				
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	(Water West Chinagetor)				
Gravel placed from ft.	Contractor's License No. 564 Date 11-30-78, 19				
and the second of the second o					