

RECEIVED
 JAN 9 1961

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
 SALEM, OREGON STATE OF OREGON

Malheur
 2316
 G1114

24/38-12M

State Well No. _____
 State Permit No. Y-1286

(1) OWNER:

Name Ross Levinger
 Address Box 309 RT 2
Ontario ORE

(2) LOCATION OF WELL:

County MALHEUR Owner's number, if any—
NW 1/4 SW 1/4 Section 12 T. 24S R. 38E W.M.
 Bearing and distance from section or subdivision corner
300 ft South and 125 East of
The West 1/4 corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
1 1/2" Diam. from 0 ft. to 20 ft. Gage 3/16
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 SIZE of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Was a surface seal provided? Yes No To what depth? _____ ft.
 Material used in seal—
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 210 ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
 [Signed] Ross Levinger date Jan 6, 1961
 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? by Him
 Yield: 800 gal./min. with 37 ft. drawdown after 8 hrs.
800 gal/min max. output oppump
 " " " " " "
 Baller test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 12 inches.
 Depth drilled 397 ft. Depth of completed well 397 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay	0	170
Rock	170	209
CRACKED LAVA ROCK	209	206
red rock	206	232
Black LAVA ROCK	232	270
porous lava rock	270	350
Brown SANDY CLAY	350	375
porous LAVA ROCK	375	397

Work started Nov 15 1960 Completed Dec 23 1960

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME H A SEVEY
 (Person, firm, or corporation) (Type or print)

Address RT. 1 Box 176 Vale ORE

Driller's well number _____

[Signed] Norman J Sevey
 (Well Driller)

License No. 17 Date Dec 23, 1960