AUG 1 1961 WATER WELL REPORT

	Malh		
<u>י</u>	284	State Well No	16/44-30 N
		State Permit No	***************************************
_			

(1) OWNER: Clara M. Scott	(11) WELL TESTS: Drawdown is amount water level lowered below static level Was a pump test made? Yes No If yes, by whom?	el is
Address Rt. 2	Yield: 550 gal./min. with 15 ft. drawdown after	4 hrs.
Vale, Oregon	. 11	**
(2) LOCATION OF WELL:	1))) 9)	
County Malheur Owner's number, if any—	Bailer test gal./min. with ft. drawdown after	hrs.
S W 14 SW 14 Section 30 T. 16 R. 44E W.M.	Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made?	Yes Cl We
Bearing and distance from section or subdivision corner		Yes No
		inches.
	Depth drilled 45 ft. Depth of completed well 4	
	Formation: Describe by color, character, size of material and str show thickness of aquifers and the kind and nature of the mate stratum penetrated, with at least one entry for each change of	rial in each
	MATERIAL FROM	TO
TYPE OF WORK (check):	top soil 0	20
Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	grabel 20	32
If abandonment, describe material and procedure in Item 11.	blue shale 32	45
PROPOSED USE (check): (5) TYPE OF WELL:		
mestic Industrial Municipal Rotary Driven		\
Cable Jetted		——
		
(6) CASING INSTALLED: Threaded Welded 5		
16" Diam from 0 nt to 34 nt Gage 3/16		
"Diam. from ft. to ft. Gage		
(7) PERFORATIONS: Perforated? 7 Yes No		
Type of perforator used Mills		
SIZE of perforations 4 in. by 2 in.		
perforations from 20 ft. to 33 ft.		+
perforations from		
perforations from ft. to ft.		
perforations from		
performance in the second seco		
/ SCREENS: Well screen installed ☐ Yes 🛎 No		
My 'ecturer's Name		
Typ. Model No.		+
Diam. Slot size Set from ft. to ft. to ft. to ft.		1
m. Slot size Set from 1t. w	Work started July 21 19 61 Completed July 2	24 19 67
(9) CONSTRUCTION:	(13) PUMP:	
gravel packed? 🗌 Yes 🗗 No Size of gravel:	Manufacturer's Name	***************************************
Gravel placed from ft. to ft.	Type: H.P	***************************************
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.	W. 11 - 11 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	
Material used in seal— Did any strata contain unusable water? Yes No	Well Driller's Statement:	
Type of water? Depth of strata	This well was drilled under my jurisdiction and this true to the best of my knowledge and belief.	report is
Method of sealing strata off	NAME H. A. Sevey	
	(Person, firm, or corporation) (Type or pr	int)
(10) WATER LEVELS: Static level 15 ft. below land surface Date 7/24/61	Address Rt. 1 Box 176 Vale, Oregon	
Artesian pressure lbs. per square inch Date	Driller's well number	
Log Accepted by:	[Signed] / 9//Cher 2	
[Signed] Date, 19	(Well Driller)	<i>(</i> -1
(Owner)	License No. 17 Date Aug. 14)	, 19 <u>0</u> .l